



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Boisfort School District

School Name: Boisfort Elementary

School Code: 2516

Address: 983 Boistfort Rd. Curtis WA 98538

County: Lewis

Number of Samples Collected: 22

Date Collected: 2/12/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample No	Program ID (See label)	Sample Type	Fixture Description	Fixture Location	Lead results (ppb)	Date of Analysis	Notes/comments
Sample 1	1501	First Draw	Tap	Kitchen	4	02/16/2018	Under window, right-hand tap used for cooking
Sample 2	1502	First Draw	Bubbler	Cafeteria	9	02/16/2018	
Sample 3	1503	First Draw	Bubbler	Gym/Locker Room	1	02/16/2018	Boy's Locker Room
Sample 4	1504	First Draw	Bubbler	Gym/Locker Room	3	02/16/2018	Girl's Locker Room
Sample 5	1505	First Draw	Bubbler	Room 21	1	02/17/2018	
Sample 6	1506	First Draw	Tap	Room 21	11	02/17/2018	
Sample 7	1507	First Draw	Bubbler	Across from Room 22	<1	02/17/2018	
Sample 8	1508	First Draw	Bubbler	Room 23	5	02/17/2018	
Sample 9	1509	First Draw	Tap	Room 23	<1	02/17/2018	
Sample 10	1510	First Draw	Bubbler	Office	6	02/17/2018	
Sample 11	1511	First Draw	Tap	Office	3	02/17/2018	
Sample 12	1512	First Draw	Bubbler	Room 26	4	02/17/2018	
Sample 13	1513	First Draw	Tap	Room 26	6	02/17/2018	
Sample 14	1514	First Draw	Bubbler	Room 27	7	02/17/2018	
Sample 15	1515	First Draw	Tap	Room 27	2	02/17/2018	
Sample 16	1516	First Draw	Bubbler	Between Rm. 27 and Rm. 28	<1	02/17/2018	
Sample 17	1517	First Draw	Bubbler	Room 28	2	02/17/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 18	1518	First Draw	Tap	Room 28	2	02/17/2018	
Sample 19	1519	First Draw	Bubbler	Room 29	10	02/17/2018	
Sample 20	1520	First Draw	Tap	Room 29	24	02/17/2018	
Sample 21	1521	First Draw	Bubbler	Room 30	11	8/1/2018	Sink was wet, tap had a slow drip
Sample 22	1522	First Draw	Tap	Room 30	92	8/1/2018	Sink was wet, tap had a slow drip