



**Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road SE, Tumwater WA 98501**

**Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**Please note: The school has participated in follow up testing and recommended remediation to help reduce children's exposure to lead in drinking water.**

**School Name:** Thompson Elementary

**School Code:** 3649

**School District Name:** Bethel

**Address:** 303 159th St E, Tacoma WA 98445

**County:** Pierce

**Number of Samples Collected:** 72

**Date Collected:** 11/08/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	16584	First Draw	Tap	Nurses Office	2	11/20/2018	6:38 AM
2.	16586	First Draw	Bubbler	Room 101	<1	11/20/2018	
3.	16587	First Draw	Tap	Room 101	1	11/20/2018	
4.	16588	First Draw	Bubbler	Room 103	<1	11/20/2018	
5.	16589	First Draw	Tap	Room 103	2	11/20/2018	
6.	16590	First Draw	Bubbler	Room 105	<1	11/20/2018	
7.	16591	First Draw	Tap	Room 105	<1	11/20/2018	
8.	16592	First Draw	Bubbler	Drinking Fountain by the Gym	2	11/20/2018	Left Side
9.	16593	First Draw	Bubbler	Drinking Fountain by the Gym	<1	11/20/2018	Right Side
10.	16594	First Draw	Tap	Kitchen	<1	11/20/2018	Food Prep Area
11.	16595	First Draw	Blank	Kitchen	1	11/20/2018	Food Prep Area
12.	16596	First Draw	Bubbler	Room 106	<1	11/20/2018	
13.	16597	First Draw	Tap	Room 106	1	11/20/2018	
14.	16598	First Draw	Bubbler	Room 104	<1	11/20/2018	
15.	16599	First Draw	Tap	Room 104	1	11/20/2018	
16.	16600	First Draw	Tap	Room 102B	3	11/20/2018	
17.	16601	First Draw	Bubbler	By Main Office	<1	11/20/2018	Left Side
18.	16602	First Draw	Bubbler , Blank	By Main Office	<1	11/20/2018	Right Side

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
19.	16603	First Draw	Bubbler	Room 152	<1	11/20/2018	
20.	16604	First Draw	Tap	Room 152	1	11/20/2018	
21.	16605	First Draw	Bubbler	Room 156	<1	11/20/2018	
22.	16606	First Draw	Tap	Room 156	5	11/20/2018	
23.	16607	First Draw	Bubbler	Room 162	1	11/20/2018	
24.	16608	First Draw	Tap	Room 162	1	11/20/2018	
25.	16610	First Draw	Bubbler	Room 164	<1	11/20/2018	
26.	16611	First Draw	Tap	Room 164	1	11/20/2018	
27.	16613	First Draw	Bubbler	Room 166	<1	11/20/2018	
28.	16614	First Draw	Tap	Room 166	1	11/20/2018	
29.	16615	First Draw	Bubbler	Room 157	<1	11/20/2018	
30.	16616	First Draw	Tap	Room 157	3	11/20/2018	
31.	16617	First Draw	Bubbler	Room 155	1	11/20/2018	
32.	16618	First Draw	Tap	Room 155	5	11/20/2018	
33.	16619	First Draw	Bubbler	Room 153	<1	11/20/2018	
34.	16620	First Draw	Tap	Room 153	1	11/20/2018	
35.	16623	First Draw	Bubbler	Room 151	<1	11/20/2018	
36.	16624	First Draw	Tap	Room 151	1	11/20/2018	
37.	16625	First Draw	Bubbler	Room 252	<1	11/20/2018	
38.	16626	First Draw	Tap	Room 252	2	11/20/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
39.	16627	First Draw	Bubbler	Room 254	<1	11/20/2018	
40.	16628	First Draw	Tap	Room 254	1	11/20/2018	
41.	16629	First Draw	Bubbler	Room 256	<1	11/20/2018	
42.	16630	First Draw	Tap	Room 256	2	11/20/2018	
43.	16631	First Draw	Bubbler	Room 257	<1	11/20/2018	
44.	16632	First Draw	Tap	Room 257	2	11/20/2018	
45.	16633	First Draw	Bubbler	Room 255	<1	11/20/2018	
46.	16634	First Draw	Tap	Room 255	4	11/20/2018	
47.	16635	First Draw	Bubbler	Room 253	<1	11/20/2018	
48.	16636	First Draw	Tap	Room 253	1	11/20/2018	
49.	16637	First Draw	Bubbler	Room 251	<1	11/20/2018	
50.	16638	First Draw	Tap	Room 251	1	11/20/2018	Used by staff member
51.	16639	First Draw	Bubbler	Room 201	<1	11/20/2018	
52.	16640	First Draw	Tap	Room 201	1	11/20/2018	
53.	16641	First Draw	Bubbler	Room 203	<1	11/20/2018	
54.	16642	First Draw	Tap	Room 203	1	11/20/2018	
55.	16643	First Draw	Bubbler	Room 205	<1	11/20/2018	
56.	16644	First Draw	Tap	Room 205	1	11/20/2018	
57.	16645	First Draw	Bubbler	Room 206	<1	11/20/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
58.	16646	First Draw	Tap	Room 206	3	11/20/2018	
59.	16647	First Draw	Bubbler	Room 204	<1	11/20/2018	
60.	16648	First Draw	Tap	Room 204	2	11/20/2018	
61.	16649	First Draw	Bubbler	Room 202	<1	11/20/2018	
62.	16650	First Draw	Tap	Room 202	2	11/20/2018	
63.	16651	First Draw	Bubbler	Room 104	2	11/20/2018	Thompson Building A
64.	16652	First Draw	Tap	Room 104	<1	11/20/2018	Thompson Building A
65.	16653	First Draw	Bubbler	Room 103	1	11/20/2018	Thompson Building A
66.	16654	First Draw	Tap	Room 103	<1	11/20/2018	Thompson Building A
67.	16655	First Draw	Bubbler	Room 102	2	11/20/2018	Thompson Building A
68.	16656	First Draw	Tap	Room 104	<1	11/20/2018	Thompson Building A
69.	16657	First Draw	Tap	Kitchen	4	11/20/2018	Thompson Building A
70.	16658	First Draw	Bubbler	Room 101	1	11/20/2018	Thompson Building A
71.	16659	First Draw	Tap	Room 101	<1	11/20/2018	Used by staff member, Thompson Building A

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
72.	16660	Blank	Blank		<1	11/20/2018	06274, Thompson Building A