



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School Name: Graham Elementary
School Code: 4297
School District Name: Bethel
Address: 10026 204th St E, Graham WA 98387
County: Pierce
Number of Samples Collected: 61
School Point of Contact: David Wells
Date Collected: 06/08/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	10744	First Draw	Tap	Nurses Office	9	09/04/2018	Calcification on tap
2.	10781	First Draw	Bubbler	Across From Room 14	2	09/04/2018	
3.	10790	First Draw	Bubbler	Room 22	10	09/04/2018	
4.	10791	First Draw	Tap	Room 22	13	09/04/2018	
5.	10792	First Draw	Bubble	Room 20	5	09/04/2018	
6.	10793	First Draw	Tap	Room 20	20	09/04/2018	
7.	10794	First Draw	Bubbler	Room 19	5	09/04/2018	
8.	10795	First Draw	Tap	Room 19	17	09/04/2018	
9.	10796	First Draw	Bubbler	Room 18	5	09/04/2018	
10.	10797	First Draw	Tap	Room 18	26	09/04/2018	
11.	10798	First Draw	Bubbler	Room 17	6	09/04/2018	
12.	10799	First Draw	Tap	Room 17	33	09/04/2018	
13.	10800	First Draw	Bubbler	Room 16	6	09/04/2018	
14.	10801	First Draw	Tap	Room 16	15	09/04/2018	
15.	10802	First Draw	Bubbler	Room 15	6	09/04/2018	
16.	10803	First Draw	Tap	Room 15	28	09/04/2018	
17.	10804	First Draw	Bubbler	Room 21	29	09/04/2018	
18.	10805	First Draw	Tap	Room 21	28	09/04/2018	
19.	10806	First Draw	Bubbler	Room 14	4	09/04/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
20.	10807	First Draw	Tap	Room 14	15	09/04/2018	
21.	10808	First Draw	Bubbler	Room 13	6	09/04/2018	
22.	10809	First Draw	Tap	Room 13	17	09/04/2018	
23.	10810	First Draw	Bubbler	Room 12	4	09/04/2018	
24.	10811	First Draw	Tap	Room 12	19	09/04/2018	
25.	10812	First Draw	Bubbler	Room 11	5	09/04/2018	
26.	10813	First Draw	Tap	Room 11	10	09/04/2018	
27.	10814	First Draw	Bubbler	Room 10	3	09/04/2018	
28.	10815	First Draw	Tap	Room 10	12	09/04/2018	No aerator
29.	10816	First Draw	Bubbler	Room 9	6	09/04/2018	
30.	10817	First Draw	Tap	Room 9	11	09/04/2018	
31.	10818	First Draw	Bubbler	Room 8	7	09/04/2018	
32.	10819	First Draw	Tap	Room 8	20	09/04/2018	Calcification on tap
33.	10820	First Draw	Bubbler	Room 7	4	09/04/2018	
34.	10821	First Draw	Tap	Room 7	12	09/04/2018	
35.	10822	First Draw	Bubbler	Room 6	7	09/04/2018	
36.	10823	First Draw	Tap	Room 6	12	09/04/2018	
37.	10824	First Draw	Bubbler	Room 5	3	09/04/2018	
38.	10825	First Draw	Tap	Room 5	10	09/04/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
39.	10826	First Draw	Bubbler	Room 4	4	09/04/2018	
40.	10827	First Draw	Tap	Room 4	7	09/04/2018	
41.	10829	First Draw	Bubbler	Room 3	1	09/04/2018	
42.	10830	First Draw	Tap	Room 3	4	09/04/2018	
43.	10831	First Draw	Bubbler	Room 23	21	09/04/2018	
44.	10832	First Draw	Tap	Room 23	14	09/04/2018	No aerator
45.	10833	First Draw	Bubbler	Room 2	31	09/04/2018	
46.	10834	First Draw	Tap	Room 2	5	09/04/2018	
47.	10835	First Draw	Bubbler	Room 1	22	09/04/2018	
48.	10836	First Draw	Tap	Room 1	3	09/04/2018	
49.	10837	First Draw	Bubbler	Across from kitchen	20	09/04/2018	
50.	10838	First Draw	Water Cooler	Portable 5	1	09/04/2018	
51.	10839	First Draw	Water Cooler	Portable 4	<1	09/04/2018	
52.	10840	First Draw	Water Cooler	Portable 3	<1	09/04/2018	
53.	10841	First Draw	Water Cooler	Portable 1	<1	09/04/2018	
54.	10842	First Draw	Water Cooler	Portable 7	<1	09/04/2018	
55.	10843	First Draw	Water Cooler	Portable 8	<1	09/04/2018	
56.	10844	First Draw	Tap	Portable 12	<1	09/04/2018	
57.	10828	First Draw	Tap	Portable 13	3	09/04/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
58.	10845	First Draw	Water Cooler	Portable 9	<1	09/04/2018	
59.	10846	First Draw	Water Cooler	Portable 10	<1	09/04/2018	
60.	10847	First Draw	Water Cooler	Portable 11	<1	09/04/2018	
61.	10848	Blank		Near entrance	<1	09/04/2018	04258