



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Lynden School District

School Name: ISOM Elementary

School Code: 4324

Address: 8461 Benson Rd Lynden WA 98264

Number of Samples Collected: 63

Date Collected: 4/10/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	6256	First Draw	Pot Filler	Kitchen	192	06/28/2018	
Sample 2	6275	First Draw	Tap	Kitchen Sink	7	06/28/2018	
Sample 3	6283	First Draw	Bubbler	Room 133	3	06/28/2018	
Sample 4	6288	First Draw	Tap	Room 133	16	06/28/2018	
Sample 5	6292	First Draw	Bubbler	Room 131	3	06/28/2018	
Sample 6	6298	First Draw	Tap	Room 131	5	06/28/2018	
Sample 7	6331	First Draw	Bubbler	Room 134	<1	06/28/2018	
Sample 8	6333	First Draw	Tap	Room 134	6	06/28/2018	No aerator
Sample 9	6334	First Draw	Bubbler	Room 130	3	06/28/2018	
Sample 10	6335	First Draw	Tap	Room 130	10	06/28/2018	
Sample 11	6336	First Draw	Drinking Fountain	Across from 135	<1	06/28/2018	
Sample 12	6337	First Draw	Bubbler	Room 135	4	06/28/2018	
Sample 13	6338	First Draw	Tap	Room 135	14	06/28/2018	
Sample 14	6339	First Draw	Bubbler	Room 136	2	06/28/2018	
Sample 15	6340	First Draw	Tap	Room 136	8	06/28/2018	
Sample 16	6341	First Draw	Bubbler	Room 123	2	06/28/2018	
Sample 17	6342	First Draw	Tap	Room 123	8	06/28/2018	
Sample 18	6346	First Draw	Bubbler	Room 122	3	06/28/2018	
Sample 19	6349	First Draw	Tap	Room 122	6	06/28/2018	
Sample 20	6367	First Draw	Bubbler	Room 137	10	06/28/2018	
Sample 21	6369	First Draw	Tap	Room 137	4	06/28/2018	
Sample 22	6370	First Draw	Bubbler	Room 138	3	06/28/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 23	6371	First Draw	Tap	Room 138	5	06/28/2018	
Sample 24	6372	First Draw	Bubbler	Room 121	7	06/28/2018	
Sample 25	6373	First Draw	Tap	Room 121	6	06/28/2018	
Sample 26	6374	First Draw	Bubbler	Room 120	12	06/28/2018	
Sample 27	6375	First Draw	Tap	Room 120	22	06/28/2018	
Sample 28	6376	First Draw	Bubbler	Room 118	3	06/28/2018	
Sample 29	6377	First Draw	Tap	Room 118	7	06/28/2018	
Sample 30	6378	First Draw	Drinking Fountain on left	Gym	<1	06/28/2018	
Sample 31	6379	First Draw	Drinking Fountain on right	Gym	<1	06/28/2018	
Sample 32	6380	First Draw	Drinking Fountain	Cafeteria	<1	06/28/2018	
Sample 33	6381	First Draw	Bubbler	Room 117	<1	06/28/2018	
Sample 34	6382	First Draw	Tap	Room 117	7	06/28/2018	
Sample 35	6383	First Draw	Bubbler	Room 116	3	06/28/2018	
Sample 36	6384	First Draw	Tap	Room 116	5	06/28/2018	
Sample 37	6385	First Draw	Bubbler	Room 115	<1	06/28/2018	
Sample 38	6386	First Draw	Tap	Room 115	4	06/28/2018	
Sample 39	6387	First Draw	Bubbler	Room 114	4	06/28/2018	
Sample 40	6388	First Draw	Tap	Room 114	6	06/28/2018	
Sample 41	6389	First Draw	Bubbler	Room 101	4	06/28/2018	
Sample 42	6390	First Draw	Tap	Room 101	13	06/28/2018	
Sample 43	6391	First Draw	Bubbler	Room 102	4	06/28/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 44	6392	First Draw	Tap	Room 102	10	06/28/2018	
Sample 45	6393	First Draw	Drinking Fountain	West of Room 114	<1	06/28/2018	
Sample 46	6394	First Draw	Bubbler	Room 110	2	06/28/2018	
Sample 47	6395	First Draw	Tap	Room 110	4	06/28/2018	
Sample 48	6396	First Draw	Bubbler	Room 109	3	06/28/2018	
Sample 49	6397	First Draw	Tap	Room 109	7	06/28/2018	
Sample 50	6398	First Draw	Bubbler	Room 107	2	06/28/2018	
Sample 51	6399	First Draw	Tap	Room 107	4	06/28/2018	
Sample 52	6400	First Draw	Bubbler	Room 106	5	06/28/2018	
Sample 53	6401	First Draw	Tap	Room 106	7	06/28/2018	
Sample 54	6402	First Draw	Bubbler	P-176	2	06/28/2018	
Sample 55	6403	First Draw	Tap	P-176	4	06/28/2018	
Sample 56	6404	First Draw	Tap	P-178	<1	06/28/2018	
Sample 57	6405	First Draw	Tap	P-175	<1	06/28/2018	
Sample 58	6406	First Draw	Tap	P-174	<1	06/28/2018	
Sample 59	6407	First Draw	Drinking Fountain	Near Main Office in Hallway	<1	06/28/2018	
Sample 60	6408	First Draw	Tap	Nurse's Office	6	06/28/2018	
Sample 61	6409	First Draw	Blank	Nurse's Office	<1	06/28/2018	05912
Sample 62	6410	First Draw	Tap	Staff Meeting Room	13	06/28/2018	No aerator

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 63	6411	First Draw	Tap	Staff Copy Room	8	06/28/2018	
Sample 64	6412	First Draw	Tap	Staff Lounge Room	3	06/28/2018	Used by staff members this morning
Sample 65	6413	First Draw	Water Cooler	Staff Lounge Room	<1	9/29/2018	