



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Sprague School District
School Name: Sprague K-12 Schools
School Code: 3050
Address: 512 S F St. Sprague WA 99032
Number of Samples Collected: 33
Date Collected: 4/17/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	4039	First Draw	Tap	1st-2nd Grade Room	<1	5/2/2018	Left-most Tap. Stand Alone Tap by the Door
Sample 2	4040	First Draw	Tap	1st-2nd Grade Room	8	5/2/2018	Right-most Tap, with attached bubbler by the windows
Sample 3	4041	First Draw	Bubbler	1st-2nd Grade Room	1	5/2/2018	
Sample 4	4042	First Draw	Tap	Kindergarten Room	2	5/2/2018	By the Door
Sample 5	4043	First Draw	Tap	Kindergarten Room	<1	5/2/2018	By the Windows with attached Bubbler
Sample 6	4044	First Draw	Bubbler	Kindergarten Room	5	5/2/2018	
Sample 7	4045	First Draw	Tap	Para Room	3	5/2/2018	
Sample 8	4046	First Draw	Bubbler	Para Room	2	5/2/2018	
Sample 9	4047	First Draw	Tap	3rd-4th Grade Room	<1	5/2/2018	
Sample 10	4048	First Draw	Bubbler	3rd-4th Grade Room	1	5/2/2018	
Sample 11	4049	First Draw	Bubbler	Across from the Nurse's Office	<1	5/2/2018	
Sample 12	4050	First Draw	Tap	Nurse's Office	<1	5/2/2018	
Sample 13	4051	First Draw	Tap	Pre-School Room	2	5/2/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 14	4052	First Draw	Tap	Pre-School Room	8	5/2/2018	
Sample 15	4053	First Draw	Bubbler	Pre-School Room	3	5/2/2018	
Sample 16	4054	First Draw	Bubbler	Across from the Gym	3	5/2/2018	Near Gym
Sample 17	4055	First Draw	Tap	Kitchen	<1	5/2/2018	Left Tap When facing the Wall
Sample 18	4056	First Draw	Tap	Kitchen	4	5/2/2018	Back wall of the Kitchen. Personal handwashing sink
Sample 19	4057	First Draw	Tap	Kitchen	<1	5/2/2018	Right Tap When facing the Wall, closest to the Cafeteria
Sample 20	4058	First Draw	Bubbler	Near Main Entrance of the Building	1	5/2/2018	Near the Main Office
Sample 21	4059	First Draw	Tap	Art Room	2	5/2/2018	
Sample 22	4060	First Draw	Tap	Home Economics Room	5	5/2/2018	Left Most Sink - By the Windows
Sample 23	4061	First Draw	Tap	Home Economics Room	1	5/2/2018	Middle Left Sink
Sample 24	4062	First Draw	Tap	Home Economics Room	1	5/2/2018	Middle Right Sink
Sample 25	4063	First Draw	Tap	Home Economics Room	<1	5/2/2018	Right Sink closest to main room door

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 26	4064	First Draw	Tap	Science Room	<1	5/2/2018	Sink Closest to back door, handwashing sink
Sample 27	4065	First Draw	Tap	Science Room	2	5/2/2018	Back wall of the Room - Left most sink near the windows
Sample 28	4066	First Draw	Tap	Science Room	2	5/2/2018	Back wall of the Room - Middle Sink
Sample 29	4067	First Draw	Tap	Science Room	1	5/2/2018	Back wall of the Room - Right most sink closest to the Door
Sample 30	4068	First Draw	Bubbler	Near Science Room	3	5/2/2018	
Sample 31	4069	First Draw	Tap	Woodshop	4	5/2/2018	
Sample 32	4070	First Draw	Tap	Computer Lab	24	5/2/2018	
Sample 33	4071	First Draw	Bubbler	Computer Lab	TB	5/2/2018	

TB = Turbidity, further analysis required