



Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following recommended remediation to help reduce children's exposure to lead in drinking water

**School District:** SedroWoolley

**School Name:** Big Lake Elementary

**School Code:** 2521

**School Address:** 16802 Lake View Blvd., Mount Vernon Washington 98274

**Number of Samples Collected:** 27

**Date Collected:** 11/02/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
27754	other	other		<1	11/19/2019	6:29 AM, 04180
27755	FirstDraw	Bubbler	Room 101	<1	11/19/2019	
27756	FirstDraw	Tap	Room 101	2	11/19/2019	
27757	FirstDraw	Bubbler	Room 102	1	11/19/2019	
27758	FirstDraw	Tap	Room 102	2	11/19/2019	
27759	FirstDraw	Tap	Health Room	<1	11/19/2019	
27760	FirstDraw	Bubbler	Near Main Office in Hallway	<1	11/19/2019	Porcelain fountain
27761	FirstDraw	Bubbler	Main Hallway Near Room 103	<1	11/19/2019	
27762	FirstDraw	Bubbler	Room 103	3	11/19/2019	
27763	FirstDraw	Tap	Room 103	2	11/19/2019	
27764	FirstDraw	Tap	Staff Lounge	<1	11/19/2019	
27766	FirstDraw	Bubbler	Room 104	<1	11/19/2019	
27767	FirstDraw	Tap	Room 104	2	11/19/2019	
27768	FirstDraw	Bubbler	Room 105	<1	11/19/2019	
27769	FirstDraw	Tap	Room 105	1	11/19/2019	
27770	FirstDraw	Bubbler	Cafeteria	<1	11/19/2019	Left Side
27771	FirstDraw	Bubbler	Cafeteria	<1	11/19/2019	Right Side
27772	Flush	BottleFiller	Cafeteria	<1	11/19/2019	
27773	FirstDraw	other	Kitchen, Sprayer	1	11/19/2019	
27774	FirstDraw	Bubbler	Library Fountains	<1	11/19/2019	Left Side
27775	FirstDraw	Bubbler	Library Fountains	<1	11/19/2019	Right Side, base leaks
27776	FirstDraw	Bubbler	Room 202	1	11/19/2019	
27777	FirstDraw	Tap	Room 202	2	11/19/2019	No Aerator
27778	FirstDraw	Bubbler	Room 201	2	11/19/2019	
27779	FirstDraw	Tap	Room 201	4	11/19/2019	
27780	FirstDraw	Bubbler	Room 203	1	11/19/2019	
27781	FirstDraw	Tap	Room 203	2	11/19/2019	No Aerator