



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Clover Park School District

School Name: Lake Louise Elementary

School Code: 3351

Address: 11014 Holden Rd Lakewood WA 98498

Number of Samples Collected: 51

Date Collected: 5/9/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	9163	First Draw	Drinking Fountain	Outside Cafeteria	3	7/6/2018	
Sample 2	9164	First Draw	Drinking Fountain	Outside Nurse's Office	4	7/6/2018	
Sample 3	9165	First Draw	Tap	Nurse's Office	7	7/6/2018	
Sample 4	9166	First Draw	Bubbler	Room 105	4	7/6/2018	
Sample 5	9167	First Draw	Bubbler Tap	Room 105	4	7/6/2018	
Sample 6	9168	First Draw	Bubbler	Room 106	3	7/6/2018	Also called Room 107
Sample 7	9169	First Draw	Tap	Room 106	5	7/6/2018	Also called Room 107
Sample 8	9170	First Draw	Bubbler	Room 301	4	7/6/2018	
Sample 9	9171	First Draw	Bubbler Tap	Room 301	4	7/7/2018	
Sample 10	9172	First Draw	Bubbler	Room 303	6	7/7/2018	
Sample 11	9173	First Draw	Bubbler Tap	Room 303	21	7/7/2018	
Sample 12	9174	First Draw	Bubbler	Room 305	2	7/7/2018	
Sample 13	9175	First Draw	Bubbler Tap	Room 305	3	7/7/2018	
Sample 14	9176	First Draw	Bubbler	Room 306	6	7/7/2018	
Sample 15	9177	First Draw	Bubbler	Room 304	4	7/7/2018	
Sample 16	9178	First Draw	Bubbler Tap	Room 304	4	7/7/2018	Leaks
Sample 17	9179	First Draw	Bubbler	Room 302	7	7/7/2018	
Sample 18	9180	First Draw	Bubbler Tap	Room 302	7	7/7/2018	
Sample 19	9181	First Draw	Bubbler	Room 401	4	7/7/2018	
Sample 20	9182	First Draw	Tap	Room 401	1	7/7/2018	
Sample 21	9183	First Draw	Bubbler	Room 403	3	7/7/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 22	9184	First Draw	Tap	Room 403	3	7/7/2018	
Sample 23	9185	First Draw	Bubbler	Room 405	7	7/7/2018	
Sample 24	9186	First Draw	Tap	Room 405	9	7/7/2018	
Sample 25	9187	First Draw	Bubbler	Room 406	4	7/7/2018	
Sample 26	9188	First Draw	Tap	Room 406	8	7/7/2018	
Sample 27	9189	First Draw	Drinking Fountain	Near 404	4	7/7/2018	
Sample 28	9190	First Draw	Bubbler	Room 404	5	7/7/2018	
Sample 29	9191	First Draw	Tap	Room 404	11	7/7/2018	
Sample 30	9192	First Draw	Bubbler	Room 402	12	7/9/2018	
Sample 31	9193	First Draw	Tap	Room 402	2	7/9/2018	
Sample 32	9194	First Draw	Bubbler	Room 501	2	7/9/2018	
Sample 33	9195	First Draw	Bubbler	Room 503	2	7/9/2018	
Sample 34	9196	First Draw	Bubbler Tap	Room 503	1	7/9/2018	
Sample 35	9197	First Draw	Bubbler	Room 505	3	7/9/2018	
Sample 36	9198	First Draw	Bubbler Tap	Room 505	3	7/9/2018	
Sample 37	9199	First Draw	Bubbler	Room 506	2	7/9/2018	
Sample 38	9200	First Draw	Bubbler Tap	Room 506	1	7/9/2018	
Sample 39	9201	First Draw	Bubbler	Room 504	3	7/9/2018	
Sample 40	9202	First Draw	Bubbler Tap	Room 504	3	7/9/2018	
Sample 41	9203	First Draw	Bubbler	Room 502	2	7/9/2018	
Sample 42	9204	First Draw	Bubbler Tap	Room 502	2	7/9/2018	
Sample 43	9205	First Draw	Drinking Fountain	Library	1	7/9/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 44	9206	First Draw	Bubbler	Room 701	2	7/9/2018	
Sample 45	9207	First Draw	Tap	Room 701	5	7/9/2018	
Sample 46	9208	First Draw	Bubbler	Room 703	3	7/9/2018	
Sample 47	9209	First Draw	Tap	Room 703	6	7/9/2018	
Sample 48	9210	First Draw	Bubbler	Room 702	2	7/9/2018	No Aerator
Sample 49	9211	First Draw	Tap	Room 702	4	7/9/2018	
Sample 50	9212	First Draw	Bubbler	Room 704	3	7/9/2018	No Aerator
Sample 51	9213	First Draw	Tap	Room 704	7	7/9/2018	
Sample 52	9214	First Draw	Blank		<1		05982

No kitchen taps tested, they are only used for dishwashing