



Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following all recommended remediation to help reduce children's exposure to lead in drinking water.

**School District:** FederalWay

**School Name:** Meredith Hill Elementary

**School Code:** 4480

**School Address:** 5830 South 300th St, Auburn Washington 98001

**Number of Samples Collected:** 66

**Date Collected:** 04/17/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
22901	other	other		<1	04/29/2019	02663, 6:45 AM
22902	FirstDraw	Tap	Nurses Office	2	04/29/2019	
22903	FirstDraw	Tap	Staff Workroom	4	04/29/2019	
22904	FirstDraw	Tap	Staff Lounge	1	04/29/2019	Tap used this morning
22905	FirstDraw	WaterCooler	Staff Lounge	<1	04/29/2019	Bottom Loading Water Cooler
22906	FirstDraw	Bubbler	Music Room	19	04/29/2019	
22907	FirstDraw	Tap	Music Room	50	04/29/2019	
22908	FirstDraw	Tap	Community Room, Room 138	3	04/29/2019	
22909	FirstDraw	Bubbler	Lobby Fountains	<1	04/29/2019	Left Side
22910	FirstDraw	Bubbler	Lobby Fountains	<1	04/29/2019	Right Side
22911	FirstDraw	Bubbler	Room 121	<1	04/29/2019	
22912	FirstDraw	Tap	Room 121	1	04/30/2019	
22913	FirstDraw	Bubbler	Room 123	<1	04/30/2019	Bubbler Drips
22914	FirstDraw	Tap	Room 123	2	04/30/2019	
22915	FirstDraw	Bubbler	Room 125	1	04/30/2019	
22916	FirstDraw	Tap	Room 125	1	04/30/2019	
22917	FirstDraw	Bubbler	Room 127	1	04/30/2019	
22918	FirstDraw	Tap	Room 127	<1	04/30/2019	
22919	FirstDraw	Bubbler	Room 124	<1	04/30/2019	
22920	FirstDraw	Tap	Room 124	1	04/29/2019	
22921	FirstDraw	Bubbler	Room 122	1	04/29/2019	
22922	FirstDraw	Tap	Room 122	2	04/29/2019	Tap Drips
22923	FirstDraw	Tap	Commons Area, 100 Hall	1	04/29/2019	Left Tap

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
22924	FirstDraw	Tap	Commons Area, 100 Hall	6	04/29/2019	Middle Tap
22925	FirstDraw	Tap	Commons Area, 100 Hall	3	04/29/2019	Right Tap
22926	FirstDraw	Tap	Library Office Sink	1	04/29/2019	
22927	FirstDraw	Bubbler	Room 114	1	04/29/2019	
22928	FirstDraw	Tap	Room 114	2	04/29/2019	Compression Valve on Tap
22929	FirstDraw	Bubbler	Room 115	1	04/29/2019	
22930	FirstDraw	Tap	Room 115	<1	04/29/2019	Compression Valve on Tap
22931	FirstDraw	Bubbler	Room 113	1	04/29/2019	
22932	FirstDraw	Tap	Room 113	<1	04/29/2019	
22933	FirstDraw	Tap	Room 111	1	04/29/2019	Bubbler wrapped in plastic, unused
22934	FirstDraw	Bubbler	Room 221	<1	04/29/2019	
22935	FirstDraw	Tap	Room 221	3	04/29/2019	Mineral deposits under Aerator
22936	FirstDraw	Bubbler	Room 223	<1	04/29/2019	
22937	FirstDraw	Tap	Room 223	1	04/29/2019	
22938	FirstDraw	Bubbler	Room 225	1	04/30/2019	
22939	FirstDraw	Tap	Room 225	1	04/30/2019	
22940	FirstDraw	Bubbler	Room 227	<1	04/30/2019	
22941	FirstDraw	Tap	Room 227	2	04/30/2019	
22942	FirstDraw	Bubbler	Room 224	<1	04/30/2019	
22943	FirstDraw	Tap	Room 224	1	04/30/2019	
22944	FirstDraw	WaterCooler	Portable 301	<1	04/30/2019	Bottom Loading Water Cooler

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
22945	FirstDraw	WaterCooler	Portable 302	<1	04/30/2019	Bottom Loading Water Cooler
22946	FirstDraw	other	Portable 303	<1	04/30/2019	Bottom Loading Water Cooler
22947	FirstDraw	Bubbler	Room 222	1	04/30/2019	
22948	FirstDraw	Tap	Room 222	1	04/30/2019	
22949	FirstDraw	Tap	D Commons, 220 Hall	1	04/30/2019	Left Tap
22950	FirstDraw	Tap	D Commons, 220 Hall	TB	NA	Middle Tap
22951	FirstDraw	Tap	D Commons, 220 Hall	1	04/30/2019	Right Tap
22952	FirstDraw	Tap	C Commons, 210 Hall	1	04/30/2019	Tap Dripping, Left Tap
22953	FirstDraw	Tap	C Commons, 210 Hall	9	04/30/2019	Middle Tap
22954	FirstDraw	Tap	C Commons, 210 Hall	4	04/30/2019	Right Tap
22955	FirstDraw	Bubbler	Room 212	<1	04/30/2019	
22956	FirstDraw	Tap	Room 212	2	04/30/2019	
22957	FirstDraw	Bubbler	Room 214	<1	04/30/2019	
22958	FirstDraw	Tap	Room 214	1	04/30/2019	
22959	FirstDraw	Bubbler	Room 217	<1	04/30/2019	
22960	FirstDraw	Tap	Room 217	1	04/30/2019	
22961	FirstDraw	Bubbler	Room 215	<1	04/30/2019	
22962	FirstDraw	Tap	Room 215	2	04/30/2019	
22963	FirstDraw	Bubbler	Room 213	1	04/30/2019	
22964	FirstDraw	Tap	Room 213	2	04/30/2019	Tap used this morning

*(continued)*

<b>Program ID</b>	<b>Sample Type</b>	<b>Description</b>	<b>Location</b>	<b>Lead Results (ppb)</b>	<b>Analysis Date</b>	<b>Comments</b>
22965	FirstDraw	Bubbler	Room 211	<1	04/30/2019	
22966	FirstDraw	Tap	Room 211	2	04/30/2019	