



Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please note: The school is following recommended remediation to help reduce children's exposure to lead in drinking water.

**School District:** TroutLake

**School Name:** Trout Lake School

**School Code:** 2676

**School Address:** 2310 WA-141, Trout Lake Washington 98650

**Number of Samples Collected:** 37

**Date Collected:** 11/27/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
29234	other	other	Blank	<1	12/12/2019	
29235	FirstDraw	Tap	Kitchen triple sink right	<1	12/19/2019	
29236	FirstDraw	Tap	Kitchen double sink	2	12/12/2019	
29237	FirstDraw	Tap	Kitchen triple sink left	10	12/12/2019	
29238	FirstDraw	Tap	Kitchen handwash sink	<1	12/12/2019	
29239	FirstDraw	Bubbler	Bubbler near entrance	<1	12/12/2019	
29240	FirstDraw	BottleFiller	Bottle filler entrance	<1	12/12/2019	
29241	FirstDraw	Tap	Nurse office/health room tap adjacent to restroom	3	12/12/2019	
29242	FirstDraw	Tap	Nurse office/health room near door	<1	12/12/2019	
29243	FirstDraw	Tap	Concession stand/room tap	10	12/12/2019	
29244	FirstDraw	Tap	Rm 139 resource room	3	12/12/2019	
29245	FirstDraw	Bubbler	Rm 139	5	12/12/2019	
29246	FirstDraw	Tap	Rm 112	1	12/12/2019	
29247	FirstDraw	Bubbler	Rm 112	3	12/12/2019	
29248	FirstDraw	Tap	Rm 138	2	12/12/2019	
29249	FirstDraw	Bubbler	Rm 138	2	12/12/2019	
29250	FirstDraw	Tap	Rm 136	1	12/12/2019	
29251	FirstDraw	Bubbler	Rm 136	2	12/12/2019	
29252	FirstDraw	Tap	Rm 135	2	12/12/2019	
29253	FirstDraw	Bubbler	Rm 135	2	12/12/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
29254	FirstDraw	Bubbler	Bubbler between rooms 135 and 134	<1	12/12/2019	
29255	FirstDraw	Tap	Rm 134	2	12/12/2019	
29256	FirstDraw	Bubbler	Rm 134	2	12/12/2019	
29257	FirstDraw	Bubbler	Gymnasium	<1	12/12/2019	
29258	FirstDraw	Tap	Staff lounge sink near fridge	1	12/12/2019	
29259	FirstDraw	Tap	Staff workroom area near lounge	53	12/12/2019	
29260	FirstDraw	Tap	Art room left tap	2	12/12/2019	
29261	FirstDraw	Tap	Art room middle tap	2	12/12/2019	
29262	FirstDraw	Tap	Art room right tap	3	12/12/2019	
29263	FirstDraw	Tap	Science room (middle school) : middle taps (left tap)	<1	12/12/2019	
29264	FirstDraw	Tap	Science room (middle school) : middle taps (right tap)	<1	12/13/2019	
29266	FirstDraw	Tap	Science room (middle school) : (leftmost tap near stove)	1	12/13/2019	

*(continued)*

<b>Program ID</b>	<b>Sample Type</b>	<b>Description</b>	<b>Location</b>	<b>Lead Results (ppb)</b>	<b>Analysis Date</b>	<b>Comments</b>
29267	FirstDraw	Bubbler	Bubbler between room 133 and 114	<1	12/13/2019	
29268	FirstDraw	Tap	Rm 109 (math)	3	12/13/2019	
29269	FirstDraw	Tap	Rm 108	2	12/13/2019	
29270	FirstDraw	Bubbler	Rm 108	1	12/13/2019	Fixture leaks from the bottom
29271	FirstDraw	Tap	Library office	<1	12/13/2019	