



Lead Sample Collection Information

School District Name: Tenino School District
School Name: Parkside Elementary School
School Code: 2457
Address: 301 Central Ave Tenino, WA 98589
Number of Samples Collected: 40
Date Collected: 2/16/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	1724	First Draw	Tap	Nurse	8	2/26/2018	
Sample 2	1719	First Draw	Bubbler	Rm. 1	4	2/26/2018	
Sample 3	1720	First Draw	Tap	Rm. 1	41	2/26/2018	
Sample 4	1721	First Draw	Bubbler	Rm. 2	2	2/26/2018	
Sample 5	1722	First Draw	Tap	Rm. 2	2	2/26/2018	
Sample 6	1723	First Draw	Bubbler	Rm. 3	1	2/26/2018	
Sample 7	1713	First Draw	Tap	Rm. 3	42	2/26/2018	
Sample 8	1706	First Draw	Bubbler	Rm. 5	3	2/26/2018	
Sample 9	1707	First Draw	Tap	Rm. 5	66	2/27/2018	
Sample 10	1708	First Draw	Bubbler	Rm. 6	3	2/26/2018	
Sample 11	1709	First Draw	Tap	Rm. 6	14	2/26/2018	
Sample 12	1710	First Draw	Bubbler	Rm. 7	3	2/26/2018	
Sample 13	1717	First Draw	Tap	Rm. 7	60	2/26/2018	
Sample 14	1712	First Draw	Bubbler	Rm. 8	5	2/26/2018	
Sample 15	1718	First Draw	Tap	Rm. 8	33	2/26/2018	
Sample 16	1714	First Draw	Bubbler	Rm. 9	1	2/26/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 17	1715	First Draw	Tap	Rm. 9	15	2/26/2018	
Sample 18	1716	First Draw	Bubbler	Rm. 10	2	2/26/2018	
Sample 19	1725	First Draw	Tap	Rm. 10	40	2/26/2018	
Sample 20	1726	First Draw	Bubbler	Rm. 11	2	2/26/2018	
Sample 21	1727	First Draw	Tap	Rm. 11	22	2/26/2018	
Sample 22	1728	First Draw	Bubbler	Rm. 12	3	2/26/2018	
Sample 23	1729	First Draw	Tap	Rm. 12	29	2/26/2018	
Sample 24	1730	First Draw	Bubbler	Rm. 13	3	2/26/2018	
Sample 25	1731	First Draw	Tap	Rm. 13	48	2/27/2018	
Sample 26	1732	First Draw	Bubbler	Rm. 14	4	2/26/2018	
Sample 27	1733	First Draw	Tap	Rm. 14	43	2/27/2018	
Sample 28	1734	First Draw	Bubbler	Next to Gym	<1	2/27/2018	Upper Left
Sample 29	1735	First Draw	Bubbler	Next to Gym	<1	2/27/2018	Lower Right
Sample 30	1736	First Draw	Bottle Filler	Next to Gym	<1	2/27/2018	Bottle Filler
Sample 31	1741	First Draw	Bubbler	P. 3	TB	2/27/2018	P= "Pepsi" Building

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 32	1742	First Draw	Tap	P. 3	5	2/27/2018	P= "Pepsi" Building
Sample 33	1737	First Draw	Bubbler	P. 4	3	2/27/2018	P= "Pepsi" Building
Sample 34	1738	First Draw	Tap	P. 4	19	2/27/2018	P= "Pepsi" Building
Sample 35	1739	First Draw	Bubbler	P. 1	16	2/27/2018	P= "Pepsi" Building
Sample 36	1740	First Draw	Tap	P. 1	17	2/27/2018	Left-hand Tap, P= "Pepsi" Building
Sample 37	1743	First Draw	Tap	P. 1	10	2/27/2018	Right-hand Tap, P= "Pepsi" Building
Sample 38	1744	First Draw	Bubbler	P. 2	12	2/27/2018	Group of 3 Fixtures P= "Pepsi" Building
Sample 39	1745	First Draw	Tap	P. 2	21	2/27/2018	Group of 3 Fixtures P= "Pepsi" Building
Sample 40	1746	First Draw	Tap	P. 2	21	2/27/2018	Group of 3 Fixtures, Left Side, Solo Tap P= "Pepsi" Building