



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please note: The school district is following all recommended remediation to help reduce children's exposure to lead in drinking water.

School District: MountBaker

School Name: Acme Elementary

School Code: 2585

School Address: 5200 Turkington Rd, Acme Washington 98244

Number of Samples Collected: 27

Date Collected: 12/19/2018

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
18260	other	other		<1	01/04/2019	12:04 AM, 06287
18261	FirstDraw	Bubbler	Room 8	3	01/04/2019	
18262	FirstDraw	Tap	Room 8	3	01/04/2019	
18379	FirstDraw	Bubbler	Room 7	5	01/04/2019	
18380	FirstDraw	Tap	Room 7	3	01/04/2019	
18422	FirstDraw	Bubbler	Room 6	6	01/04/2019	
18423	FirstDraw	Tap	Room 6	4	01/04/2019	No Aerator
18424	FirstDraw	Bubbler	Room 5	5	01/04/2019	
18425	FirstDraw	Tap	Room 5	3	01/04/2019	
18426	FirstDraw	Bubbler	Next to Room 6	2	01/05/2019	
18427	FirstDraw	Bubbler	Between Room 5 and 4	<1	01/05/2019	
18428	FirstDraw	Bubbler	Room 4	3	01/05/2019	Loose fixture and erratic flow
18429	FirstDraw	Tap	Room 4	2	01/05/2019	No Aerator
18430	FirstDraw	Bubbler	Room 2	4	01/05/2019	
18431	FirstDraw	Tap	Room 2	8	01/05/2019	
18432	FirstDraw	Tap	Supply Closet	2	01/05/2019	
18433	FirstDraw	Bubbler	West Side of Gym	<1	01/05/2019	
18434	FirstDraw	Bubbler	East Side of Gym	1	01/05/2019	
18435	FirstDraw	Bubbler	Room 12	<1	01/05/2019	
18436	FirstDraw	Tap	Room 12	1	01/05/2019	
18437	FirstDraw	Tap	Resource Room	1	01/05/2019	
18438	FirstDraw	Tap	Staff Workroom	1	01/05/2019	
18439	FirstDraw	Tap	Room 13	1	01/05/2019	Bubbler non-functioning
18440	FirstDraw	Bubbler	Room 14	<1	01/05/2019	
18441	FirstDraw	Tap	Room 14	1	01/05/2019	
18442	FirstDraw	Bubbler	Room 15	<1	01/05/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
18443	FirstDraw	Tap	Room 15	2	01/05/2019	