



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school has notified the department that all fixtures with lead levels about 10ppb were replaced. The school has also implemented flushing program at all fixtures.

School Name: Kenroy Elementary School

School Code: 3212

School District Name: Eastmont

Address: 601 N Jonathan Ave, East Wenatchee WA 98802

County: Douglas

Number of Samples Collected: 49

Date Collected: 10/05/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	12851	First Draw	Tap	Nurses station	<1	10/11/2018	
2.	12852	First Draw	Bubbler	Room 401	<1	10/11/2018	
3.	12853	First Draw	Tap	Room 401	1	10/11/2018	
4.	12854	First Draw	Bubbler	Room 403	4	10/11/2018	Right
5.	12855	First Draw	Tap	Room 402	9	10/11/2018	Right
6.	12856	First Draw	Bubbler	Room 402	3	10/11/2018	Left
7.	12857	First Draw	Tap	Room 402	24	10/11/2018	Left
8.	12858	First Draw	Bubbler	Inside office	1	10/11/2018	
9.	12859	First Draw	Bubbler	Gym	<1	10/11/2018	Left right no pressure
10.	12860	First Draw	Bubbler	Room 101	3	10/11/2018	
11.	12861	First Draw	Tap	Room 101	4	10/11/2018	
12.	12862	First Draw	Bubbler	Room 102	2	10/11/2018	
13.	12863	First Draw	Tap	Room 102	4	10/11/2018	
14.	12864	First Draw	Bubbler	Room 104	2	10/11/2018	
15.	12865	First Draw	Tap	Room 104	4	10/11/2018	
16.	12866	First Draw	Bubbler	Room 103	3	10/11/2018	
17.	12867	First Draw	Tap	Room 103	3	10/11/2018	
18.	12868	First Draw	Bubbler	Room 105	7	10/17/2018	
19.	12869	First Draw	Tap	Room 105	4	10/17/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
20.	12870	First Draw	Bubbler	Room 106	6	10/11/2018	
21.	12871	First Draw	Tap	Room 106	<1	10/11/2018	
22.	12872	First Draw	Bubbler	Room 206	12	10/11/2018	
23.	12873	First Draw	Tap	Room 206	2	10/11/2018	
24.	12874	First Draw	Tap	Room 209	1	10/11/2018	
25.	12875	First Draw	Tap	Room 207	7	10/11/2018	
26.	12876	First Draw	Bubbler	Room 207	5	10/11/2018	
27.	12877	First Draw	Tap	Room 201	8	10/11/2018	
28.	12878	First Draw	Bubbler	Room 201	2	10/11/2018	
29.	12879	First Draw	Tap	Room 203	4	10/11/2018	
30.	12880	First Draw	Bubbler	Room 203	2	10/11/2018	
31.	12881	First Draw	Tap	Room 204	5	10/11/2018	
32.	12882	First Draw	Bubbler	Room 204	1	10/11/2018	
33.	12883	First Draw	Tap	Room 202	4	10/11/2018	
34.	12884	First Draw	Bubbler	Room 202	1	10/11/2018	
35.	12885	First Draw	Bubbler	Portable 308	1	10/11/2018	
36.	12886	First Draw	Bubbler	Portable 307	<1	10/11/2018	Left
37.	12887	First Draw	Bubbler	Portable 307	<1	10/11/2018	Right
38.	12888	First Draw	Bubbler	Portable 306	<1	10/11/2018	
39.	12889	First Draw	Bubbler	Portable 305	<1	10/11/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
40.	12890	First Draw	Bubbler	Room 302	<1	10/11/2018	
41.	12891	First Draw	Tap	Room 302	1	10/11/2018	
42.	12892	First Draw	Bubbler	Room 301	1	10/11/2018	
43.	12893	First Draw	Tap	Room 302	4	10/11/2018	
44.	12894	First Draw	Bubbler	Room 304	2	10/11/2018	
45.	12895	First Draw	Tap	Room 304	15	10/11/2018	
46.	12896	First Draw	Bubbler	Room 303	1	10/11/2018	
47.	12897	First Draw	Tap	Room 303	9	10/11/2018	
48.	12898	First Draw	Tap	Kitchen	<1	10/11/2018	
49.	12899	First Draw	Blank	Blank	<1	10/11/2018	