



Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school district is following all recommended remediation to help reduce children's overall exposure to lead in drinking water.

**School District:** Highline

**School Name:** Southern Heights Elementary

**School Code:** 3032

**School Address:** 11249 14th Ave S, Seattle Washington 98168

**Number of Samples Collected:** 41

**Date Collected:** 12/05/2018

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
16873	other	other		<1	12/26/2018	6:25AM, 06245
16875	FirstDraw	Tap	Kitchen	2	12/26/2018	First compartment sink, filter on tap
17034	FirstDraw	Bubbler	Gym	2	12/26/2018	
17035	FirstDraw	Tap	Nurses Office	15	01/17/2019	
17036	FirstDraw	Tap	Staff Lounge	3	12/26/2018	
17037	FirstDraw	Bubbler	Across from Staff Lounge	9	12/26/2018	
17038	FirstDraw	Tap	Portable 1	1	12/26/2018	
17039	FirstDraw	Bubbler	Room 1	1	01/17/2019	
17040	FirstDraw	Tap	Room 1	9	12/26/2018	
17041	FirstDraw	Bubbler	Room 2	<1	12/26/2018	
17042	FirstDraw	Tap	Room 2	8	12/26/2018	
17043	FirstDraw	Bubbler	Room 3	<1	12/26/2018	
17044	FirstDraw	Tap	Room 3	13	12/26/2018	
17045	FirstDraw	Bubbler	Room 4	<1	12/26/2018	
17046	FirstDraw	Tap	Room 4	14	12/26/2018	No aerator
17047	FirstDraw	Bubbler	Room 5	6	01/17/2019	Water is discolored
17048	FirstDraw	Tap	Room 5	8	01/17/2019	
17049	FirstDraw	Bubbler	Room 6	<1	12/26/2018	
17050	FirstDraw	Tap	Room 6	13	12/26/2018	
17051	FirstDraw	Bubbler	Room 7	5	01/17/2019	Water dribbles
17052	FirstDraw	Tap	Room 7	37	01/17/2019	
17053	FirstDraw	Bubbler	Room 8	<1	12/26/2018	
17054	FirstDraw	Tap	Room 8	14	12/26/2018	
17055	FirstDraw	other	Room 9	<1	12/26/2018	
17056	FirstDraw	Bubbler	Room 9	2	12/26/2018	
17057	FirstDraw	Tap	Room 9	29	12/26/2018	
17058	FirstDraw	Bubbler	Room 10	2	12/26/2018	
17059	FirstDraw	Tap	Room 10	3	12/26/2018	

*(continued)*

<b>Program ID</b>	<b>Sample Type</b>	<b>Description</b>	<b>Location</b>	<b>Lead Results (ppb)</b>	<b>Analysis Date</b>	<b>Comments</b>
17100	FirstDraw	Bubbler	Room 12	<1	12/26/2018	
17125	FirstDraw	Tap	Room 12	2	12/26/2018	
17126	FirstDraw	Bubbler	Room 11	1	12/26/2018	
17127	FirstDraw	Tap	Room 11	12	12/26/2018	
17128	FirstDraw	Bubbler	Library	14	01/17/2019	
17129	FirstDraw	Bubbler	Room 13	<1	12/26/2018	
17130	FirstDraw	Tap	Room 13	2	12/26/2018	Tap Dripping
17131	FirstDraw	Bubbler	Room 14	1	12/26/2018	
17132	FirstDraw	Tap	Room 14	1	12/26/2018	
17133	FirstDraw	Bubbler	Room 15	1	12/26/2018	
17134	FirstDraw	Tap	Room 15	3	12/26/2018	
17135	FirstDraw	Bubbler	Room 16	5	01/17/2019	
17136	FirstDraw	Tap	Room 16	18	01/17/2019	