



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Prosser School District
School Name: Whitstran Elementary School
School Code: 2905
Address: 102101 W. Foisy Road Prosser WA 99350
Number of Samples Collected: 27
Date Collected: 3/29/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	2984	First Draw	Bubbler	Outside Room 1	7	05/15/2018	
Sample 2	2985	First Draw	Bubbler	Room 1	<1	05/15/2018	
Sample 3	2986	First Draw	Tap	Room 1	1	05/15/2018	
Sample 4	2987	First Draw	Bubbler	Nurses Station	3	05/15/2018	
Sample 5	2988	First Draw	Tap	Nurses Station	1	05/15/2018	
Sample 6	2989	First Draw	Bubbler	Room 3	5	05/15/2018	
Sample 7	2990	First Draw	Tap	Room 3	<1	05/15/2018	
Sample 8	2991	First Draw	Bubbler	Room 4	<1	05/15/2018	
Sample 9	2992	First Draw	Tap	Room 4	1	05/15/2018	
Sample 10	2993	First Draw	Bubbler	Room 5	<1	05/15/2018	
Sample 11	2994	First Draw	Tap	Room 5	2	05/15/2018	
Sample 12	2995	First Draw	Bubbler	Room 6	<1	05/15/2018	
Sample 13	2996	First Draw	Tap	Room 6	1	05/15/2018	
Sample 14	2997	First Draw	Bubbler	Room 7	<1	05/15/2018	
Sample 15	2998	First Draw	Tap	Room 7	1	05/15/2018	
Sample 16	2999	First Draw	Bubbler	Outside Room 7	<1	05/15/2018	
Sample 17	3000	First Draw	Tap	Room 9	1	05/15/2018	
Sample 18	3001	First Draw	Bubbler	Room 9	1	05/15/2018	
Sample 19	3002	First Draw	Tap	Room 8	<1	05/15/2018	
Sample 20	3003	First Draw	Bubbler	Room 8	2	05/15/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 21	3004	First Draw	Tap	Portable 17	<1	05/15/2018	all bathroom taps in portable are used for drinking as evidenced by cups near sink
Sample 22	3005	First Draw	Tap	Portable 12	<1	05/15/2018	
Sample 23	3006	First Draw	Tap	Portable 13	<1	05/15/2018	
Sample 24	3007	First Draw	Tap	Portable 10	<1	05/15/2018	
Sample 25	3008	First Draw	Tap	Portable 11	<1	05/15/2018	
Sample 26	3009	First Draw	Tap	Portable 19	<1	05/15/2018	
Sample 27	3010	First Draw	Tap	Portable 20	<1	05/15/2018	
Sample 28	3011	First Draw	Tap	BLANK	<1	05/15/2018	