



Lead Sample Collection Information

Disclaimer: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Oak Harbor School District

School Name: Broadview Elementary

School Code: 3477

Address: 350 S Oak Harbor St Oak Harbor WA 98277

Number of Samples Collected: 46

Date Collected: 2/24/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	1182	First Draw	Sprayer	Kitchen	1	3/5/2018	
Sample 2	1183	First Draw	Sink Tap	Left Sink Tap in Kitchen	2	3/5/2018	
Sample 3	1184	First Draw	Sink Tap	Right Sink Tap in Kitchen	1	3/5/2018	
Sample 4	1185	First Draw	Standalone sprayer and sink	Kitchen	7	3/5/2018	
Sample 5	1186	First Draw	Sink Tap	Health Room	1	3/5/2018	
Sample 6	1188	First Draw	Lower Left Fountain	Main Office Hallway	<1	3/5/2018	
Sample 7	1189	First Draw	Higher Right Fountain	Main Office Hallway	<1	3/5/2018	
Sample 8	1190	First Draw	Sink Tap	B104	3	3/5/2018	
Sample 9	1191	First Draw	Bubbler	B104	<1	3/5/2018	
Sample 10	1192	First Draw	Sink Tap	B103	2	3/5/2018	
Sample 11	1193	First Draw	Bubbler	B103	1	3/5/2018	
Sample 12	1194	First Draw	Sink Tap	B109	4	3/5/2018	
Sample 13	1195	First Draw	Bubbler	B109	1	3/5/2018	
Sample 14	1196	First Draw	Sink Tap	B108	2	3/5/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 15	1197	First Draw	Bubbler	B108	<1	3/5/2018	
Sample 16	1198	First Draw	Sink Tap	C104	2	3/5/2018	
Sample 17	1199	First Draw	Bubbler	C104	<1	3/5/2018	
Sample 18	1200	First Draw	Sink Tap	C103	4	3/5/2018	
Sample 19	1201	First Draw	Bubbler	C103	<1	3/5/2018	
Sample 20	1202	First Draw	Sink Tap	C108	50	3/5/2018	
Sample 21	1203	First Draw	Sink Tap	C109	4	3/5/2018	
Sample 22	1204	First Draw	Bubbler	C109	1	3/5/2018	
Sample 23	1205	First Draw	Sink Tap	D109	<1	3/5/2018	
Sample 24	1206	First Draw	Bubbler	D109	<1	3/5/2018	
Sample 25	1207	First Draw	Sink Tap	D108	3	3/5/2018	
Sample 26	1208	First Draw	Bubbler	D108	<1	3/5/2018	
Sample 27	1209	First Draw	Sink Tap	D104	2	3/5/2018	
Sample 28	1210	First Draw	Bubbler	D104	<1	3/5/2018	
Sample 29	1211	First Draw	Sink Tap	D103	3	3/5/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 30	1212	First Draw	Bubbler	D103	<1	3/5/2018	
Sample 31	1213	First Draw	Sink Tap	E104	2	3/5/2018	
Sample 32	1214	First Draw	Bubbler	E104	<1	3/5/2018	
Sample 33	1215	First Draw	Sink Tap	E103	2	3/5/2018	
Sample 34	1216	First Draw	Bubbler	E103	<1	3/5/2018	
Sample 35	1217	First Draw	Sink Tap	E109	1	3/5/2018	
Sample 36	1218	First Draw	Bubbler	E109	<1	3/5/2018	
Sample 37	1219	First Draw	Sink Tap	E108	2	3/5/2018	
Sample 38	1220	First Draw	Bubbler	E108	<1	3/5/2018	
Sample 39	1221	First Draw	Sink Tap	F104	2	3/5/2018	
Sample 40	1230	First Draw	Bubbler	F104	<1	3/5/2018	
Sample 41	1222	First Draw	Sink Tap	F103	2	3/5/2018	
Sample 42	1223	First Draw	Bubbler	F103	<1	3/5/2018	
Sample 43	1224	First Draw	Sink Tap	F109	2	3/5/2018	
Sample 44	1225	First Draw	Bubbler	F109	1	3/5/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 45	1226	First Draw	Sink Tap	F108	3	3/5/2018	
Sample 46	1227	First Draw	Bubbler	F108	<1	3/5/2018	