



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following all recommended remediation to help reduce children's exposure to lead in drinking water.

School District: Mukilteo

School Name: Olympic View Middle School

School Code: 3120

School Address: 2602 Mukilteo Speedway, Mukilteo Washington 98275

Number of Samples Collected: 45

Date Collected: 05/23/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
24095	other	other		<1	06/13/2019	06605, 5:59 AM
24096	FirstDraw	Tap	Kitchen	<1	06/13/2019	Food Prep Area
24097	FirstDraw	Bubbler	Cafeteria	<1	06/13/2019	
24098	FirstDraw	Bubbler	Outside Room D3	<1	06/13/2019	Mineral deposits near spout
24099	FirstDraw	Tap	Health Room	2	06/13/2019	
24100	FirstDraw	Tap	Library Office	5	06/13/2019	
24501	FirstDraw	Bubbler	1st Floor A Building, Near Elevator	1	06/13/2019	
24502	FirstDraw	Tap	Room A100	9	06/13/2019	
24503	FirstDraw	Tap	Room A101	4	06/13/2019	Tap Dripping
24504	FirstDraw	Tap	Room A102	8	06/13/2019	Mineral deposits around aerator
24505	FirstDraw	Tap	Room A104	4	06/13/2019	
24506	FirstDraw	Tap	Room A105	5	06/13/2019	
24507	FirstDraw	Tap	Room A103	5	06/13/2019	
24508	FirstDraw	Tap	Room A106	5	06/13/2019	
24509	Flush	Tap	Room A107	1	06/13/2019	
24510	FirstDraw	Tap	Room A108	3	06/13/2019	Mineral deposits in aerator
24511	FirstDraw	Tap	Room A109	1	06/14/2019	
24512	FirstDraw	Tap	Room A211	3	06/14/2019	
24513	FirstDraw	Tap	Room A201, By Window	4	06/14/2019	Handle Broken

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
24514	FirstDraw	Tap	Room A200	6	06/14/2019	
24515	FirstDraw	Bubbler	A Building, 2nd floor near elevator	<1	06/14/2019	
24517	FirstDraw	Tap	Room C106	<1	06/14/2019	Used this morning
24518	FirstDraw	Tap	Room C105	1	06/14/2019	
24519	FirstDraw	Bubbler	Across from Room C107	<1	06/14/2019	
24520	FirstDraw	Tap	Room C110 (HOME)	<1	06/14/2019	Head of Classroom Sink
24521	FirstDraw	Tap	Room C110 (HOME)	<1	06/14/2019	Kitchen 1
24522	FirstDraw	Tap	Room C110 (HOME)	<1	06/14/2019	Kitchen 2
24523	FirstDraw	Tap	Room C110 (HOME)	<1	06/14/2019	Kitchen 3
24524	FirstDraw	Tap	Room C110 (HOME)	<1	06/14/2019	Kitchen 4
24525	FirstDraw	Tap	Room C110 (HOME)	<1	06/14/2019	Kitchen 5
24526	FirstDraw	Tap	Room C110 (HOME)	<1	06/14/2019	Kitchen 6
24527	FirstDraw	Tap	Room C111, Near Window	2	06/14/2019	Art Room
24528	FirstDraw	Tap	Room C111	5	06/14/2019	Left Side Sink in Art Room opposite window
24529	FirstDraw	Tap	Room C111	4	06/14/2019	Art Room, Right Side Sink
24530	FirstDraw	Bubbler	Cycle Room	<1	06/14/2019	E Building
24531	FirstDraw	BottleFiller	Cycle Room	<1	06/14/2019	E Building

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
24532	FirstDraw	Bubbler	In Gym	<1	06/14/2019	
24533	FirstDraw	BottleFiller	In Gym	<1	06/14/2019	
24534	FirstDraw	Bubbler	Outside Gym	<1	06/14/2019	Left Fountain
24535	FirstDraw	Bubbler	Outside Gym	<1	06/14/2019	Right Fountain
24536	FirstDraw	BottleFiller	Outside Gym	<1	06/14/2019	
24537	FirstDraw	Bubbler	Room 110	<1	06/14/2019	
24538	FirstDraw	Tap	Room 110	<1	06/14/2019	
24539	FirstDraw	Bubbler	Room 111	<1	06/14/2019	
24540	FirstDraw	Tap	Room 111	<1	06/14/2019	