



Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school has participated in follow up testing and recommended remediation to help reduce children's exposure to lead in drinking water.

**School District:** Highline

**School Name:** Cascade Middle School

**School Code:** 3163

**School Address:** 11212 10th Ave SW, Seattle Washington 98146

**Number of Samples Collected:** 39

**Date Collected:** 02/21/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
18999	FirstDraw	Tap	Rm 104	<1	03/13/2019	
19000	FirstDraw	Tap	Rm 109	24	03/13/2019	
19001	FirstDraw	Bubbler	Next to Nurse	<1	03/01/2019	
19002	FirstDraw	BottleFiller	Next to Nurse	<1	03/01/2019	
19003	FirstDraw	Tap	Nurse	10	03/13/2019	
19004	FirstDraw	Tap	Rm 119	3	03/13/2019	
19005	FirstDraw	Bubbler	Next to Rm 402	1	03/01/2019	
19006	FirstDraw	Bubbler	Next to Rm 405	2	03/13/2019	
19007	FirstDraw	Bubbler	Next to Rm 304	<1	03/13/2019	
19008	FirstDraw	Tap	Rm 302	10	03/01/2019	
19009	FirstDraw	Tap	Rm 301	7	03/01/2019	
19010	FirstDraw	Tap	Rm 303	11	03/01/2019	
19011	FirstDraw	Tap	Rm 305	1	03/13/2019	
19012	FirstDraw	Tap	Rm 309	1	03/01/2019	South sink
19013	FirstDraw	Tap	Rm 309	2	03/13/2019	North sink
19014	FirstDraw	Bubbler	Next to Rm 309	1	03/01/2019	
19015	FirstDraw	Tap	Rm 605	5	03/13/2019	Righthand, left not in use
19016	FirstDraw	Tap	Rm 704	24	03/01/2019	
19017	FirstDraw	Tap	Rm 706	10	03/22/2019	Fast drip
19018	FirstDraw	Bubbler	Next to Rm 706	<1	03/01/2019	Left
19019	FirstDraw	Bubbler	Next to Rm 706	<1	03/01/2019	Right
19020	FirstDraw	Tap	Rm 708	18	03/01/2019	
19021	FirstDraw	Tap	Rm 707	6	03/01/2019	
19022	FirstDraw	Tap	Rm 705	17	03/01/2019	
19023	FirstDraw	Tap	Rm 703	100	03/22/2019	
19024	FirstDraw	Tap	Rm 701	9	03/01/2019	
19025	FirstDraw	Bubbler	Gym #1	<1	03/01/2019	
19026	FirstDraw	Bubbler	Outside Rm 529	18	03/22/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
19027	FirstDraw	Bubbler	Gym #2	<1	03/01/2019	East
19028	FirstDraw	Bubbler	Gym #2	<1	03/01/2019	West
19029	FirstDraw	Bubbler	Girls Locker Room	1	03/22/2019	
19030	FirstDraw	Bubbler	Outside gyms	1	03/22/2019	Across from vending machines
19031	FirstDraw	Tap	Kitchen	<1	03/01/2019	Single and triple left tap
19032	FirstDraw	Tap	Kitchen	<1	03/01/2019	Triple sink right
19033	FirstDraw	Bubbler	Cafeteria	10	03/22/2019	
19034	FirstDraw	Bubbler	Next to Rm 203	<1	03/22/2019	
19035	FirstDraw	Tap	Rm 203	<1	03/01/2019	
19036	FirstDraw	Bubbler	Next to Rm 213	<1	03/22/2019	
19037	other			<1	03/01/2019	