



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Upon notification of the results, the school removed and replaced all fixtures that had lead levels above 9ppb and above.

School Name: Black Lake Elementary School

School Code: 4205

School District Name: Tumwater

Address: 7741 Littlerock Road SW, Olympia WA 98512

County: Thurston

Number of Samples Collected: 57

Date Collected: 11/08/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	17616				<1	11/21/2018	
2.	17617	First Draw	Tap	Nurse	<1	11/21/2018	
3.	17618	First Draw	Bubbler	Gym	<1	11/21/2018	
4.	17619	First Draw	Tap	Kitchen	50	11/21/2018	Left tap, triple sink next to convection steamer
5.	17620	First Draw	Tap	Kitchen	11	11/21/2018	Right tap, triple sink next to convection steamer
6.	17621	First Draw		Kitchen	3	11/21/2018	Sprayer, triple sink next to convection steamer
7.	17622	First Draw	Pot Filler	Kitchen	7	11/21/2018	
8.	17623	First Draw	Bubbler	Rm 25	3	11/21/2018	
9.	17624	First Draw	Tap	Rm 25	11	11/21/2018	
10.	17625	First Draw	Bubbler	Rm 26	10	11/21/2018	
11.	17626	First Draw	Tap	Rm 26	17	11/21/2018	
12.	17627	First Draw	Bubbler	Next to music room ramp	3	11/21/2018	
13.	17628	First Draw	Tap	Music room	11	11/21/2018	
14.	17629	First Draw	Bubbler	Multipurpose Room	7	11/21/2018	Left

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
15.	17630	First Draw	Bubbler	Multipurpose Room	1	11/21/2018	Right
16.	17631	First Draw	Bubbler	4th/5th Grade Pod Common	2	11/21/2018	
17.	17632	First Draw	Tap	4th/5th Grade Pod Common	1	11/21/2018	
18.	17633	First Draw	Bubbler	Rm 18	2	11/21/2018	
19.	17634	First Draw	Tap	Rm 18	1	11/21/2018	
20.	17635	First Draw	Bubbler	Rm 17	6	11/21/2018	
21.	17636	First Draw	Tap	Rm 17	6	11/21/2018	
22.	17637	First Draw	Bubbler	Rm 16	1	11/21/2018	
23.	17638	First Draw	Tap	Rm 16	2	11/21/2018	
24.	17639	First Draw	Bubbler	Rm 15	3	11/21/2018	
25.	17640	First Draw	Tap	Rm 15	1	11/21/2018	
26.	17641	First Draw	Bubbler	Rm 14	4	11/22/2018	
27.	17642	First Draw	Tap	Rm 14	2	11/22/2018	
28.	17643	First Draw	Bubbler	Rm 13	3	11/22/2018	
29.	17644	First Draw	Tap	Rm 13	2	11/22/2018	Slow drip
30.	17645	First Draw	Bubbler	2nd/3rd Grade Pod Common	10	11/22/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
31.	17646	First Draw	Tap	2nd/3rd Grade Pod Common	11	11/22/2018	
32.	17647	First Draw	Bubbler	Rm 12	5	11/22/2018	
33.	17648	First Draw	Tap	Rm 12	5	11/22/2018	Very slow drip
34.	17649	First Draw	Bubbler	Rm 11	1	11/22/2018	
35.	17650	First Draw	Tap	Rm 11	1	11/22/2018	
36.	17651	First Draw	Bubbler	Rm 10	1	11/22/2018	
37.	17652	First Draw	Tap	Rm 10	1	11/22/2018	
38.	17653	First Draw	Bubbler	Rm 9	7	11/22/2018	
39.	17654	First Draw	Tap	Rm 9	2	11/22/2018	
40.	17655	First Draw	Bubbler	Rm 8	4	11/22/2018	
41.	17656	First Draw	Tap	Rm 8	9	11/22/2018	Slow drip
42.	17657	First Draw	Bubbler	Rm 7	2	11/22/2018	
43.	17658	First Draw	Tap	Rm 7	1	11/22/2018	
44.	17659	First Draw	Bubbler	K/1st Grade Common	1	11/22/2018	
45.	17660	First Draw	Tap	K/1st Grade Common	1	11/22/2018	
46.	17661	First Draw	Bubbler	Rm 6	1	11/22/2018	
47.	17662	First Draw	Tap	Rm 6	1	11/22/2018	
48.	17663	First Draw	Bubbler	Rm 5	3	11/22/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
49.	17664	First Draw	Tap	Rm 5	4	11/22/2018	
50.	17665	First Draw	Bubbler	Rm 4	2	11/22/2018	
51.	17666	First Draw	Tap	Rm 4	1	11/22/2018	
52.	17667	First Draw	Bubbler	Rm 3	<1	11/22/2018	
53.	17668	First Draw	Tap	Rm 3	<1	11/22/2018	
54.	17669	First Draw	Bubbler	Rm 2	15	11/22/2018	
55.	17670	First Draw	Tap	Rm 2	<1	11/22/2018	
56.	17671	First Draw	Bubbler	Rm 1	<1	11/22/2018	
57.	17672	First Draw	Tap	Rm 1	<1	11/22/2018	