



### **Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**School District Name: Evergreen School District**

**School Name: Sifton Elementary School**

**School Code: 3149**

**Address: 7301 NE 137th Ave Vancouver WA 98682**

**Number of Samples Collected: 43**

**Date Collected: 3/14/2018**

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
<b>Sample 1</b>	4510	First Draw	Blank	Blank	<1	3/22/2018	Blank
<b>Sample 2</b>	4511	First Draw	Bubbler	Rm. 101	4	3/22/2018	
<b>Sample 3</b>	4512	First Draw	Tap	Rm. 101	43	3/22/2018	
<b>Sample 4</b>	4513	First Draw	Bubbler	Rm. 103	2	3/22/2018	
<b>Sample 5</b>	4514	First Draw	Tap	Rm. 103	4	3/22/2018	
<b>Sample 6</b>	4515	First Draw	Bubbler	Rm. 105	3	3/22/2018	
<b>Sample 7</b>	4516	First Draw	Tap	Rm. 105	1	3/22/2018	
<b>Sample 8</b>	4517	First Draw	Bubbler	Rm. 107	3	3/22/2018	
<b>Sample 9</b>	4518	First Draw	Tap	Rm. 107	1	3/22/2018	
<b>Sample 10</b>	4519	First Draw	Bubbler	Rm. 108	2	3/22/2018	
<b>Sample 11</b>	4520	First Draw	Tap	Rm. 108	1	3/22/2018	
<b>Sample 12</b>	4521	First Draw	Bubbler	Rm. 106	3	3/22/2018	
<b>Sample 13</b>	4522	First Draw	Tap	Rm. 106	1	3/22/2018	
<b>Sample 14</b>	4523	First Draw	Bubbler	Rm. 104	3	3/22/2018	
<b>Sample 15</b>	4524	First Draw	Tap	Rm. 104	6	3/22/2018	
<b>Sample 16</b>	4525	First Draw	Bubbler	Rm. 102	3	3/22/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
<b>Sample 17</b>	4526	First Draw	Tap	Rm. 102	4	3/23/2018	
<b>Sample 18</b>	4527	First Draw	Bubbler	Next to Front Desk	<1	3/23/2018	
<b>Sample 19</b>	4528	First Draw	Bottle Filler	Next to Front Desk	<1	3/23/2018	
<b>Sample 20</b>	4529	First Draw	Tap	Kitchen	2	3/23/2018	To left of computer station, Left-hand tap, small leak during use
<b>Sample 21</b>	4530	First Draw	Tap	Kitchen	1	3/23/2018	To left of computer station, Right-hand tap
<b>Sample 22</b>	4531	First Draw	Bubbler	Rm. 202	3	3/23/2018	
<b>Sample 23</b>	4532	First Draw	Tap	Rm. 202	4	3/23/2018	
<b>Sample 24</b>	4533	First Draw	Bubbler	Rm. 203	3	3/23/2018	
<b>Sample 25</b>	4534	First Draw	Tap	Rm. 203	2	3/23/2018	
<b>Sample 26</b>	4535	First Draw	Bubbler	Rm. 204	1	3/23/2018	
<b>Sample 27</b>	4536	First Draw	Tap	Rm. 204	2	3/23/2018	
<b>Sample 28</b>	4537	First Draw	Bubbler	Rm. 205	9	3/23/2018	
<b>Sample 29</b>	4538	First Draw	Tap	Rm. 205	<1	3/23/2018	
<b>Sample 30</b>	4539	First Draw	Bubbler	Rm. 302	21	3/23/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
<b>Sample 31</b>	4540	First Draw	Tap	Rm. 302	11	3/23/2018	
<b>Sample 32</b>	4541	First Draw	Bubbler	Rm. 303	19	3/23/2018	
<b>Sample 33</b>	4542	First Draw	Tap	Rm. 303	19	3/23/2018	
<b>Sample 34</b>	4543	First Draw	Bubbler	Rm. 304	15	3/23/2018	
<b>Sample 35</b>	4544	First Draw	Tap	Rm. 304	10	3/23/2018	
<b>Sample 36</b>	4545	First Draw	Bubbler	Rm. 305	8	3/23/2018	
<b>Sample 37</b>	4546	First Draw	Tap	Rm. 305	6	3/23/2018	
<b>Sample 38</b>	4547	First Draw	Bubbler	Rm. 306	1	3/23/2018	
<b>Sample 39</b>	4548	First Draw	Tap	Rm. 306	3	3/23/2018	
<b>Sample 40</b>	4549	First Draw	Bubbler	Rm. 307	5	3/23/2018	
<b>Sample 41</b>	4550	First Draw	Tap	Rm. 307	9	3/23/2018	
<b>Sample 42</b>	4552	First Draw	Bubbler	Rm. 308	10	3/23/2018	
<b>Sample 43</b>	4553	First Draw	Tap	Rm. 308	8	3/23/2018	Small leak during use