



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District: BainbridgeIsland

School Name: Sakai Intermediate School

School Code: 4542

School Address: 9343 Sportsman Club Rd NE, Bainbridge Island Washington 98110

Number of Samples Collected: 76

Date Collected: 02/28/2020

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
26568	other			<1	03/06/2020	NA
26569	FirstDraw	Tap	Kitchen island double sink across from kettle	2	03/06/2020	NA
26570	FirstDraw	other	Kitchen dishwashing hose on pot filler next to kettle	10	03/06/2020	NA
26571	FirstDraw	PotFiller	Pot filler next to kettle	6	03/06/2020	NA
26572	FirstDraw	Tap	Kitchen single sink on back wall	6	03/06/2020	NA
26573	FirstDraw	Tap	Kitchen triple sink: left	2	03/06/2020	NA
26574	FirstDraw	Tap	Kitchen triple sink: right	2	03/06/2020	NA
26575	FirstDraw	other	Kitchen triple sink: dishwashing hose	2	03/06/2020	NA
26576	FirstDraw	other	Kitchen cooking appliance next to triple sink	57	03/13/2020	NA
26577	FirstDraw	Bubbler	Gym bubbler	<1	03/06/2020	NA
26578	FirstDraw	Bubbler	Hall bubbler next to rm 252	<1	03/06/2020	NA
26580	FirstDraw	Tap	Rm 239	1	03/06/2020	NA
26581	FirstDraw	Bubbler	Rm 239	1	03/06/2020	NA
26582	FirstDraw	Tap	Rm 240	2	03/06/2020	NA

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
26583	FirstDraw	Bubbler	Rm 240	<1	03/06/2020	NA
26584	FirstDraw	Tap	Staff workroom	<1	03/06/2020	NA
26585	FirstDraw	Tap	Health station	<1	03/06/2020	NA
26586	FirstDraw	Tap	223	<1	03/06/2020	NA
26587	FirstDraw	Bubbler	223	<1	03/06/2020	NA
26588	FirstDraw	Tap	224	<1	03/06/2020	NA
26589	FirstDraw	Bubbler	224	<1	03/06/2020	NA
26590	FirstDraw	Tap	225	<1	03/06/2020	NA
26591	FirstDraw	Bubbler	225	<1	03/06/2020	NA
26592	FirstDraw	Tap	226	<1	03/06/2020	NA
26593	FirstDraw	Bubbler	226	<1	03/06/2020	NA
26594	FirstDraw	Tap	229	3	03/06/2020	NA
26595	FirstDraw	Bubbler	229	1	03/06/2020	NA
26596	FirstDraw	Tap	228	<1	03/06/2020	NA
26597	FirstDraw	Bubbler	228	<1	03/06/2020	NA
26598	FirstDraw	Tap	227	<1	03/06/2020	NA
26599	FirstDraw	Bubbler	227	<1	03/06/2020	NA
26600	FirstDraw	Tap	Library office 219A	4	03/06/2020	NA
26601	FirstDraw	Tap	201	<1	03/06/2020	NA
26602	FirstDraw	Tap	218	<1	03/06/2020	NA
26603	FirstDraw	Tap	208	<1	03/06/2020	NA
26604	FirstDraw	Bubbler	208	<1	03/06/2020	NA
26605	FirstDraw	Tap	207	<1	03/06/2020	NA
26606	FirstDraw	Bubbler	207	<1	03/07/2020	NA
26607	FirstDraw	Tap	206	<1	03/07/2020	NA
26608	FirstDraw	Bubbler	206	<1	03/07/2020	NA
26609	FirstDraw	Tap	203	6	03/07/2020	NA
26610	FirstDraw	Bubbler	203	1	03/07/2020	NA
26611	FirstDraw	Tap	204	<1	03/07/2020	NA
26612	FirstDraw	Bubbler	204	<1	03/07/2020	NA
26613	FirstDraw	Tap	205	<1	03/07/2020	NA

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
26614	FirstDraw	Bubbler	205	<1	03/07/2020	NA
26615	FirstDraw	Tap	124	<1	03/07/2020	NA
26616	FirstDraw	Bubbler	124	<1	03/07/2020	NA
26617	FirstDraw	Tap	125	<1	03/07/2020	NA
26618	FirstDraw	Bubbler	125	<1	03/07/2020	NA
26619	FirstDraw	Tap	126	<1	03/07/2020	NA
26620	FirstDraw	Bubbler	126	<1	03/07/2020	NA
26621	FirstDraw	Tap	129	1	03/07/2020	NA
26622	FirstDraw	Bubbler	129	5	03/07/2020	NA
26623	FirstDraw	Tap	128	<1	03/07/2020	NA
26624	FirstDraw	Bubbler	128	<1	03/07/2020	NA
26625	FirstDraw	Tap	127	<1	03/07/2020	NA
26626	FirstDraw	Bubbler	127	<1	03/07/2020	NA
26627	FirstDraw	Tap	Rm 123: tap/bubbler combo sink	<1	03/07/2020	NA
26628	FirstDraw	Bubbler	Rm 123: tap/bubbler combo sink	<1	03/07/2020	NA
26629	FirstDraw	Tap	119	1	03/07/2020	NA
26630	FirstDraw	Bubbler	119	1	03/07/2020	NA
26631	FirstDraw	Tap	Rm 109: tap/bubbler combo sink	<1	03/07/2020	NA
26632	FirstDraw	Bubbler	Rm 109: tap/bubbler combo sink	<1	03/07/2020	NA
26633	FirstDraw	Tap	108	<1	03/07/2020	NA
26634	FirstDraw	Bubbler	108	<1	03/07/2020	NA
26635	FirstDraw	Tap	107	<1	03/07/2020	NA
26636	FirstDraw	Bubbler	107	<1	03/07/2020	NA
26637	FirstDraw	Tap	106	<1	03/07/2020	NA
26638	FirstDraw	Bubbler	106	<1	03/07/2020	NA
26639	FirstDraw	Tap	103	22	03/13/2020	NA
26640	FirstDraw	Bubbler	103	12	03/13/2020	NA
26641	FirstDraw	Tap	104	<1	03/07/2020	NA

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
26642	FirstDraw	Bubbler	104	<1	03/07/2020	NA
26643	FirstDraw	Tap	105	<1	03/07/2020	NA
26644	FirstDraw	Bubbler	105	<1	03/07/2020	NA