



**Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road SE, Tumwater WA 98501**

**Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**School District Name:** Auburn

**School Name:** Dick Scobee Elementary

**School Code:** 2932

**Address:** 1031 14th St NE, Auburn WA 98002

**County:** King

**Number of Samples Collected:** 47

**Date Collected:** 06/14/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	10921	First Draw	Tap	Kitchen Sink in back	TB		6:30 AM, Left Sink, No aerator, Tap used that morning
2.	10922	First Draw	Tap	Kitchen sink in back	TB		Right Sink, No Aerator, Tap used that morning
3.	10923	First Draw	Bubbler	Drinking fountain across from Kitchen	2	07/06/2018	
4.	10924	First Draw	Tap	Nurses Office	6	07/06/2018	
5.	10925	First Draw	Bubbler	Room 201	1	07/06/2018	
6.	10926	First Draw	Tap	Room 201	2	07/06/2018	
7.	10927	First Draw	Bubbler	Room 202	<1	07/06/2018	
8.	10928	First Draw	Tap	Room 202	TB		
9.	10929	First Draw	Bubbler	Room 203	TB		
10.	10930	First Draw	Tap	Room 203	TB		
11.	10931	First Draw	Bubbler	Room 204	1	07/06/2018	
12.	10932	First Draw	Tap	Room 204	1	07/06/2018	
13.	10933	First Draw	Bubbler	Room 205	4	07/06/2018	
14.	10934	First Draw	Tap	Room 205	2	07/06/2018	
15.	10935	First Draw	Bubbler	Room 206	1	07/06/2018	
16.	10936	First Draw	Tap	Room 206	TB		
17.	10937	First Draw	Bubbler	Room 306	<1	07/06/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
18.	10938	First Draw	Tap	Room 306	1	07/06/2018	
19.	10939	First Draw	Bubbler	Room 305	<1	07/06/2018	
20.	10940	First Draw	Tap	Room 305	<1	07/06/2018	
21.	10941	First Draw	Bubbler	Room 304	1	07/06/2018	
22.	10942	First Draw	Tap	Room 304	TB		
23.	10943	First Draw	Bubbler	Room 303	<1	07/06/2018	
24.	10944	First Draw	Tap	Room 303	1	07/06/2018	
25.	10945	First Draw	Bubbler	Room 302	4	07/06/2018	
26.	10946	First Draw	Tap	Room 302	6	07/06/2018	
27.	10947	First Draw	Bubbler	Room 501	2	07/06/2018	
28.	10948	First Draw	Tap	Room 501	<1	07/06/2018	
29.	10973	First Draw	Bubbler	Room 502	1	07/06/2018	
30.	10974	First Draw	Tap	Room 502	1	07/06/2018	
31.	10975	First Draw	Bubbler	Room 503	1	07/06/2018	
32.	10976	First Draw	Tap	Room 503	TB		
33.	10977	First Draw	Bubbler	Room 504	1	07/06/2018	
34.	10978	First Draw	Tap	Room 504	4	07/06/2018	
35.	10979	First Draw	Bubbler	Room 505	<1	07/06/2018	
36.	10980	First Draw	Tap	Room 505	<1	07/06/2018	
37.	11341	First Draw	Bubbler	Room 506	1	07/06/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
38.	11342	First Draw	Tap	Room 506	<1	07/06/2018	
39.	11343	First Draw	Tap	Music Room	TB		
40.	11344	First Draw	Bubbler	Room 404	<1	07/06/2018	
41.	11345	First Draw	Tap	Room 404	<1	07/06/2018	
42.	11346	First Draw	Bubbler	Room 403	1	07/06/2018	
43.	11347	First Draw	Tap	Room 403	<1	07/06/2018	
44.	11348	First Draw	Bubbler	Room 402	<1	07/06/2018	
45.	11349	First Draw	Tap	Room 402	1	07/06/2018	
46.	11350	First Draw	Bubbler	Gym	<1	07/06/2018	
47.	11351	Blank	Blank	Near entrance	<1	07/06/2018	03476

TB= Turbidity, further analysis required.