



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Yakima School District

School Name: Nob Hill Elementary

School Code: 2819

Address: 801 S 34th Ave Yakima WA 98902

Number of Samples Collected: 49

Date Collected:3/21/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	2945	First Draw	Tap	Kitchen	<1	06/01/2018	
Sample 2	2946	First Draw	Bubbler	Outside Office	<1	06/01/2018	
Sample 3	2947	First Draw	Water bottle station	Outside Office	<1	06/01/2018	
Sample 4	2948	First Draw	Tap	Nurses Station	1	06/01/2018	
Sample 5	2949	First Draw	Tap	Room 6	<1	06/01/2018	
Sample 6	2950	First Draw	Bubbler	Room 6	<1	06/01/2018	
Sample 7	2951	First Draw	Tap	Room 5	3	06/01/2018	
Sample 8	2952	First Draw	Bubbler	Room 5	<1	06/01/2018	
Sample 9	2953	First Draw	Tap	Room 4	2	06/01/2018	
Sample 10	2954	First Draw	Bubbler	Room 4	<1	06/01/2018	
Sample 11	2955	First Draw	Tap	Room 3	<1	06/01/2018	
Sample 12	2956	First Draw	Bubbler	Room 3	1	06/01/2018	
Sample 13	2957	First Draw	Tap	Room 2	<1	06/01/2018	
Sample 14	2958	First Draw	Bubbler	Room 2	<1	06/01/2018	
Sample 15	2959	First Draw	Tap	Room 1	3	06/01/2018	
Sample 16	2960	First Draw	Bubbler	Outside Room 1	<1	06/01/2018	
Sample 17	2961	First Draw	Tap	Room 7	1	06/01/2018	
Sample 18	2962	First Draw	Bubbler	Room 7	2	06/01/2018	
Sample 19	2963	First Draw	Tap	Room 8	1	06/01/2018	
Sample 20	2964	First Draw	Bubbler	Room 8	<1	06/01/2018	
Sample 21	2965	First Draw	Tap	Room 9	1	06/01/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 22	2966	First Draw	Bubbler	Room 9	<1	06/01/2018	
Sample 23	2967	First Draw	Tap	Room 10	1	06/01/2018	
Sample 24	2968	First Draw	Bubbler	Room 10	3	06/01/2018	
Sample 25	2969	First Draw	Tap	Room 11	<1	06/01/2018	
Sample 26	2970	First Draw	Bubbler	Room 11	<1	06/01/2018	
Sample 27	2971	First Draw	Tap	Inside Library	<1	06/01/2018	
Sample 28	2972	First Draw	Bubbler	Inside Library	<1	06/01/2018	
Sample 29	2973	First Draw	Tap	Room 13	<1	06/01/2018	
Sample 30	2974	First Draw	Bubbler	Room 13	<1	06/01/2018	
Sample 31	2975	First Draw	Tap	Room 15	<1	06/01/2018	
Sample 32	2976	First Draw	Bubbler	Room 15	<1	06/01/2018	
Sample 33	2977	First Draw	Bubbler	Outside Room 15	<1	06/01/2018	
Sample 34	2978	First Draw	Bubbler	Room 16	<1	06/01/2018	
Sample 35	2979	First Draw	Tap	Room 16	1	06/01/2018	
Sample 36	2980	First Draw	Bubbler	Room 17	<1	06/01/2018	
Sample 37	2909	First Draw	Tap	Room 17	1	6/1/2018	
Sample 38	2910	First Draw	Bubbler	Room 18	<1	6/1/2018	
Sample 39	2911	First Draw	Tap	Room 18	1	06/01/2018	
Sample 40	2912	First Draw	Bubbler	Room 19	<1	06/01/2018	
Sample 41	2913	First Draw	Tap	Room 19	<1	06/01/2018	
Sample 42	2914	First Draw	Bubbler	Room 20	<1	06/01/2018	
Sample 43	2915	First Draw	Tap	Room 20	1	06/01/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 44	2916	First Draw	Bubbler	Room 29	<1	06/01/2018	
Sample 45	2917	First Draw	Tap	Room 29	<1	06/01/2018	
Sample 46	2918	First Draw	Bubbler	Room 28	<1	06/01/2018	
Sample 47	2919	First Draw	Tap	Room 28	<1	06/01/2018	
Sample 48	2920	First Draw	Tap	Room 27	<1	06/01/2018	
Sample 49	2921	First Draw	Tap	Room 25	5	06/01/2018	
Sample 50	2922	First Draw	BLANK	BLANK	<1	06/01/2018	