



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Date Collected: 08/23/2018
School Name: Hayes Freedom High School
School Code: 5104
School District Name: Camas
Address: 1919 NE Ione St, Camas WA 98607
County: Clark
Number of Samples Collected: 2
Date sent to State Lab: 08/24/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	11821	First Draw	Tap	Nurses Station	16	08/28/2018	9:35AM collection time
2.	11822			In building	<1	08/28/2018	03484