



### **Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**School District Name: Pasco School District**  
**School Name: Ruth Livingston Elementary School**  
**School Code: 4041**  
**Address: 2515 N. Rd. 84 Franklin, WA 99301**  
**Number of Samples Collected: 32**  
**Date Collected: 4/13/2018**

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	4007	First Draw	Tap	Room A1	1	5/8/2018	
Sample 2	4008	First Draw	Bubbler	Room A1	<1	5/8/2018	
Sample 3	4009	First Draw	Tap	Room A2	1	5/8/2018	
Sample 4	4010	First Draw	Bubbler	Room A2	<1	5/8/2018	
Sample 5	4011	First Draw	Tap	Room A3	1	5/8/2018	
Sample 6	4012	First Draw	Bubbler	Room A3	<1	5/8/2018	
Sample 7	4013	First Draw	Tap	Portable 1	1	5/8/2018	
Sample 8	4014	First Draw	Bubbler	Portable 1	4	5/8/2018	Drips at the Base
Sample 9	4015	First Draw	Tap	Portable 2	5	5/8/2018	
Sample 10	4016	First Draw	Bubbler	Portable 2	1	5/8/2018	
Sample 11	4017	First Draw	Tap	Portable 3	10	5/8/2018	Tap Drips
Sample 12	4018	First Draw	Bubbler	Portable 3	<1	5/8/2018	
Sample 13	4019	First Draw	Tap	Portable 4	TB	5/8/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 14	4020	First Draw	Bubbler	Portable 4	TB	5/8/2018	
Sample 15	4021	First Draw	Tap	Portable 7	TB	5/8/2018	
Sample 16	4022	First Draw	Bubbler	Portable 7	3	5/8/2018	
Sample 17	4023	First Draw	Tap	Portable 8	5	5/8/2018	
Sample 18	4024	First Draw	Tap	Portable 9	4	5/8/2018	
Sample 19	4025	First Draw	Tap	Portable 10	TB	5/8/2018	
Sample 20	4026	First Draw	Tap	Portable 11	TB	5/8/2018	
Sample 21	4027	First Draw	Tap	Portable 16	<1	5/8/2018	
Sample 22	4028	First Draw	Bubbler	Portable 16	<1	5/8/2018	
Sample 23	4029	First Draw	Tap	Portable 17	<1	5/8/2018	
Sample 24	4030	First Draw	Bubbler	Portable 17	<1	5/8/2018	
Sample 25	4031	First Draw	Tap	Portable 12	2	5/8/2018	
Sample 26	4032	First Draw	Bubbler	Portable 12	TB	5/8/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 27	4033	First Draw	Tap	Portable 13	1	5/8/2018	
Sample 28	4034	First Draw	Bubbler	Portable 13	<1	5/8/2018	
Sample 29	4035	First Draw	Tap	Portable 14	1	5/8/2018	
Sample 30	4036	First Draw	Bubbler	Portable 14	<1	5/8/2018	
Sample 31	4037	First Draw	Tap	Portable 15	TB	5/8/2018	
Sample 32	4038	First Draw	Bubbler	Portable 15	TB	5/8/2018	

TB= Turbidity further analysis required.