



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following recommended remediation to help reduce children's exposure to lead in drinking water.

School District: FederalWay

School Name: Totem Middle School

School Code: 3431

School Address: 26630 40th Ave South, Kent Washington 98032

Number of Samples Collected: 37

Date Collected: 01/09/2020

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
30797	other	other		<1	01/21/2020	09578, 5:52 AM
30798	FirstDraw	Bubbler	Cafeteria	<1	01/21/2020	
30799	FirstDraw	Tap	Kitchen, Single Outlet Sink in Middle of Kitchen	17	02/10/2020	
30800	FirstDraw	Bubbler	Room 48	5	01/21/2020	
30801	FirstDraw	Tap	Room 48	4	02/10/2020	
30802	FirstDraw	Bubbler	Gym, Near Boys Locker Room	1	01/21/2020	
30803	FirstDraw	Bubbler	Boys Locker Room	<1	01/21/2020	
30804	FirstDraw	Bubbler	Hallway Outside of Gym	<1	01/21/2020	Left
30805	FirstDraw	Bubbler	Hallway Outside of Gym	<1	01/21/2020	Right
30806	FirstDraw	Bubbler	Outside Room 30	4	01/21/2020	
30807	FirstDraw	Bubbler	Outside Room 30	4	01/21/2020	Right
30808	FirstDraw	Bubbler	Hallway Fountain Next to Room 14 and Room 12	1	01/21/2020	
30809	FirstDraw	Bubbler	In Hallway Near Main Offices	<1	01/21/2020	Used this morning
30810	FirstDraw	Tap	Workroom Near Main Office	38	01/21/2020	
30811	FirstDraw	Bubbler	In Hallway across from Room 38	2	01/21/2020	Left
30812	FirstDraw	Bubbler	In Hallway across from Room 38	2	01/21/2020	Right

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
30814	FirstDraw	Tap	Room 40	8	01/21/2020	Sink on Left, Sink on Right is not being used
30815	FirstDraw	Tap	Room 41	12	01/21/2020	
30817	FirstDraw	Tap	Room 42 in Backroom	7	01/21/2020	
30818	FirstDraw	Bubbler	Room 43	<1	01/21/2020	Only spot students drink from in room
30819	FirstDraw	Tap	Room 4, Portable	7	02/10/2020	Only water source in portable area
30927	FirstDraw	Tap	Room 32	13	02/10/2020	
30928	FirstDraw	Tap	Room 39	10	02/10/2020	
30929	FirstDraw	Tap	Room 37	10	02/10/2020	Used for hand washing, teacher wants the tap tested
30930	FirstDraw	Tap	Room 25	16	02/10/2020	Tap Dripping, Water Discolored
30931	FirstDraw	Tap	Room 24	25	02/10/2020	Some water discoloration
30932	FirstDraw	Tap	Room 23	8	01/21/2020	Tap Dripping
30933	FirstDraw	Tap	Office Library	16	01/21/2020	
30934	FirstDraw	Tap	Health Room	9	01/21/2020	
30935	FirstDraw	Tap	Staff Lounge	<1	01/21/2020	Tap Dripping, Used this morning
30936	FirstDraw	Tap	Room 18	27	01/21/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
30937	FirstDraw	Tap	Room 16, Starting on West Side of Room moving clockwise	17	01/21/2020	Moving clockwise from 1st tap on west side, Tap in front of room and far right tap on east side not used by students
30938	FirstDraw	Tap	Room 16, West Side of Room moving clockwise	16	01/21/2020	
30939	FirstDraw	Tap	Room 16, West Side of Room moving clockwise	18	01/21/2020	West Side of Room, Last Tap on West Wall
30940	FirstDraw	Tap	Room 16, Tap on East Side of Room moving clockwise	7	01/21/2020	First tap on left on east side of room
30941	FirstDraw	Tap	Room 16, Tap on East Side moving clockwise	43	01/21/2020	2nd tap from left on east side of room
30942	FirstDraw	Tap	Room 17	2	01/21/2020	