



### **Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**School District Name: Centralia School District**

**School Name: Jefferson Lincoln Elementary School**

**School Code: 3172**

**Address: 400 West Summa**

**County: Lewis**

**Number of Samples Collected: 38**

**Date Collected: 5/2/2018**

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	6150	First Draw	Blank	Blank	<1	7/6/2018	Blank
Sample 2	6151	First Draw	Bubbler	Rm. 1	1	7/26/2018	Irregular Function
Sample 3	6152	First Draw	Tap	Rm. 1	2	7/6/2018	
Sample 4	6153	First Draw	Bubbler	Rm. 2	<1	7/6/2018	
Sample 5	6154	First Draw	Tap	Rm. 2	<1	7/6/2018	
Sample 6	6155	First Draw	Bubbler	Rm. 3	1	7/6/2018	
Sample 7	6156	First Draw	Tap	Rm. 3	2	7/6/2018	
Sample 8	6157	First Draw	Bubbler	Rm. 4	2	7/6/2018	
Sample 9	6158	First Draw	Tap	Rm. 4	1	7/6/2018	
Sample 10	6159	First Draw	Bubbler	Rm. 5	4	7/6/2018	
Sample 11	6160	First Draw	Tap	Rm. 5	5	7/6/2018	
Sample 12	6161	First Draw	Bubbler	Rm. 6	<1	7/6/2018	
Sample 13	6162	First Draw	Tap	Rm. 6	<1	7/6/2018	
Sample 14	6163	First Draw	Bubbler	Rm. 18	8	7/6/2018	
Sample 15	6164	First Draw	Tap	Rm. 18	42	7/6/2018	
Sample 16	6165	First Draw	Bubbler	Rm. 19	3	8/20/2018	
Sample 17	6166	First Draw	Tap	Rm. 19	2	7/6/2018	
Sample 18	6167	First Draw	Tap	Rm. 20	6	7/6/2018	Bubbler no function
Sample 19	6168	First Draw	Bubbler	Rm. 21	15	8/20/2018	
Sample 20	6169	First Draw	Tap	Rm. 21	141	8/20/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 21	6170	First Draw	Bubbler	Rm. 9	4	7/6/2018	
Sample 22	6171	First Draw	Tap	Rm. 9	3	7/6/2018	
Sample 23	6172	First Draw	Bubbler	Rm. 10	18	7/6/2018	
Sample 24	6173	First Draw	Tap	Rm. 10	26	7/6/2018	
Sample 25	6174	First Draw	Bubbler	Rm. 11	<1	7/6/2018	
Sample 26	6175	First Draw	Tap	Rm. 11	9	7/6/2018	
Sample 27	6176	First Draw	Bubbler	Rm. 12	9	7/6/2018	
Sample 28	6178	First Draw	Tap	Rm. 12	105	7/6/2018	
Sample 29	6179	First Draw	Bubbler	Rm. 14	1	7/6/2018	
Sample 30	6180	First Draw	Tap	Rm. 14	16	7/6/2018	
Sample 31	5501	First Draw	Bubbler	Rm. 16	5	7/6/2018	
Sample 32	5502	First Draw	Tap	Rm. 16	25	8/20/2018	
Sample 33	5503	First Draw	Bubbler	Rm. 17	4	7/6/2018	
Sample 34	5504	First Draw	Tap	Rm. 17	21	7/6/2018	
Sample 35	5505	First Draw	Bubbler	Rm. 15	5	7/6/2018	
Sample 36	5506	First Draw	Tap	Rm. 15	120	8/20/2018	
Sample 37	5507	First Draw	Tap	Health Room	3	7/6/2018	Sink next to refrigerators
Sample 38	5508	First Draw	Tap	Kitchen	5	8/20/2018	Spray nozzle only, used for cleaning produce, no cooking water, may have been used

