



### **Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**School District Name: Toledo School District**

**School Name: Toledo High School**

**School Code: 2616**

**Address: 1242 State Route 505 Toledo WA 98591**

**Number of Samples Collected: 10**

**Date Collected: 2/14/2018**

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	1696	First Draw	Tap	Kitchen	7	2/17/2018	Tap to Right of Dish Washing Machine
Sample 2	1697	First Draw	Bubbler	Commons	4	2/17/2018	Next to Award Plaques
Sample 3	1698	First Draw	Bottle Filler	Commons	5	2/17/2018	Next to Award Plaques
Sample 4	1699	First Draw	Bubbler	Gym	4	2/17/2018	
Sample 5	1700	First Draw	Bubbler	Near Counselor's Room	9	2/17/2018	
Sample 6	1701	First Draw	Tap	Home Economics	12	2/17/2018	Left Most, Nearest door
Sample 7	1702	First Draw	Tap	Home Economics	12	2/17/2018	2nd From Door
Sample 8	1703	First Draw	Tap	Home Economics	18	2/17/2018	3rd, In corner
Sample 9	1704	First Draw	Tap	Home Economics	64	2/17/2018	4th from door
Sample 10	1705	First Draw	Tap	Home Economics	63	2/17/2018	Furthest from Door