



### **Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**School District Name: Oak Harbor School District**

**School Name: Hillcrest Elementary**

**School Code: 4328**

**Address: 1500 NW 2nd Ave Oak Harbor WA 98277**

**Number of Samples Collected: 61**

**Date Collected: 2/24/2018**

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	1121	First Draw	Sprayer	Kitchen	1	3/14/2018	
Sample 2	1122	First Draw	Sink Tap	Kitchen	3	3/14/2018	May have mechanical issues
Sample 3	1123	First Draw	Left Drinking Fountain	Gym	<1	3/14/2018	
Sample 4	1124	First Draw	Right Drinking Fountain	Gym	<1	3/14/2018	
Sample 5	1125	First Draw	Sink Tap	Health Room	2	3/14/2018	
Sample 6	1126	First Draw	Sink Tap	Room 29, 1st room	16	3/14/2018	
Sample 7	1127	First Draw	Bubbler	Room 29, 1st room	2	3/14/2018	
Sample 8	1128	First Draw	Sink Tap	Room 28	<1	3/14/2018	
Sample 9	1129	First Draw	Bubbler	Room 28	<1	3/14/2018	
Sample 10	1130	First Draw	Sink Tap	Room 27	1	3/14/2018	Metal Art Room Sink
Sample 11	1131	First Draw	Sink Tap	Room 26	10	3/14/2018	
Sample 12	1132	First Draw	Bubbler	Room 26	<1	3/14/2018	
Sample 13	1133	First Draw	Sink Tap	Room 25	12	3/14/2018	
Sample 14	1134	First Draw	Bubbler	Room 25	<1	3/14/2018	
Sample 15	1135	First Draw	Sink Tap	Pod C Outer Sink	3	3/14/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
				Near Room 19			
Sample 16	1136	First Draw	Drinking Fountain	Pod C Outer Drinking Fountain Near 19	<1	3/14/2018	
Sample 17	1137	First Draw	Sink Tap	Room 24	17	3/14/2018	
Sample 18	1138	First Draw	Bubbler	Room 24	<1	3/14/2018	
Sample 19	1139	First Draw	Sink Tap	Room 23	14	3/14/2018	
Sample 20	1140	First Draw	Bubbler	Room 23	<1	3/14/2018	
Sample 21	1141	First Draw	Sink Tap	Room 22	7	3/14/2018	
Sample 22	1142	First Draw	Bubbler	Room 22	<1	3/14/2018	
Sample 23	1143	First Draw	Sink Tap	Room 21	<1	3/14/2018	
Sample 24	1144	First Draw	Bubbler	Room 21	<1	3/14/2018	
Sample 25	1145	First Draw	Sink Tap	Room 20	6	3/14/2018	
Sample 26	1146	First Draw	Bubbler	Room 20	<1	3/14/2018	
Sample 27	1147	First Draw	Sink Tap	Room 19	<1	3/14/2018	
Sample 28	1148	First Draw	Bubbler	Room 19	1	3/14/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 29	1149	First Draw	Sink Tap	Room 17	19	3/14/2018	
Sample 30	1150	First Draw	Bubbler	Room 17	<1	3/14/2018	
Sample 31	1151	First Draw	Sink Tap	Room 16	21	3/14/2018	
Sample 32	1152	First Draw	Bubbler	Room 16	1	3/14/2018	
Sample 33	1153	First Draw	Sink Tap	Room 15	14	3/14/2018	
Sample 34	1154	First Draw	Bubbler	Room 15	1	3/14/2018	
Sample 35	1155	First Draw	Sink Tap	Room 14	9	3/14/2018	
Sample 36	1156	First Draw	Bubbler	Room 14	<1	3/14/2018	
Sample 37	1157	First Draw	Sink Tap	Room 13	11	3/14/2018	
Sample 38	1158	First Draw	Bubbler	Room 13	<1	3/14/2018	
Sample 39	1159	First Draw	Sink Tap	Room 12	4	3/14/2018	
Sample 40	1160	First Draw	Bubbler	Room 12	1	3/14/2018	
Sample 41	1161	First Draw	Sink Tap	Room 11	13	3/14/2018	
Sample 42	1162	First Draw	Bubbler	Room 11	<1	3/14/2018	
Sample 43	1163	First Draw	Sink Tap	Outer Pod B Sink	5	3/14/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 44	1164	First Draw	Drinking Fountain	Outer Pod B. Drinking Fountain	<1	3/14/2018	
Sample 45	1165	First Draw	Sink Tap	Room 1	3	3/14/2018	
Sample 46	1166	First Draw	Bubbler	Room 1	<1	3/14/2018	Type: HAWS
Sample 47	1167	First Draw	Sink Tap	Room 10	17	3/14/2018	
Sample 48	1168	First Draw	Bubbler	Room 10	1	3/14/2018	
Sample 49	1169	First Draw	Sink Tap	Room 9	9	3/14/2018	
Sample 50	1170	First Draw	Bubbler	Room 9	<1	3/14/2018	
Sample 51	1171	First Draw	Sink Tap	Room 8	6	3/14/2018	
Sample 52	1172	First Draw	Bubbler	Room 8	<1	3/14/2018	
Sample 53	1173	First Draw	Sink Tap	Room 7	6	3/14/2018	
Sample 54	1174	First Draw	Bubbler	Room 7	<1	3/14/2018	
Sample 55	1175	First Draw	Sink Tap	Room 6	3	3/14/2018	
Sample 56	1176	First Draw	Bubbler	Room 6	<1	3/14/2018	
Sample 57	1177	First Draw	Sink Tap	Room 5	12	3/14/2018	
Sample 58	1178	First Draw	Bubbler	Room 5	<1	3/14/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 59	1179	First Draw	Sink Tap	Room 4	7	3/14/2018	
Sample 60	1180	First Draw	Bubbler	Room 4	<1	3/14/2018	
Sample 61	1181	First Draw	Sink Tap	Outer Pod A. Near Room 4	2	3/14/2018	