



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please note. The school has complied with our recommendations and have gone a step further by replacing all fixtures that had lead levels greater than 10ppb and participated in more volunteer testing through this program.

School District Name: Colfax school District

School Name: Leonard M. Jennings Elementary School

School Code: 2894

Address: 1207 N. Morton St. Colfax, WA 99111

Number of Samples Collected: 11

Date Collected: 5/22/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	8194		BLANK	BLANK	<1	5/29/2018	
Sample 2	8195	First Draw	Tap	Room 125	4	5/29/2018	
Sample 3	8196	First Draw	Tap	Room 120	4	5/29/2018	
Sample 4	8197	First Draw	Tap	Room 127	7	5/29/2018	
Sample 5	8198	First Draw	Tap	Room 121	10	5/29/2018	
Sample 6	8199	First Draw	Tap	Room 122	6	5/29/2018	
Sample 7	8200	First Draw	Tap	Room 128	4	5/29/2018	
Sample 8	8201	First Draw	Tap	Room 129	6	5/29/2018	
Sample 9	8202	First Draw	Tap	Room 148	6	5/29/2018	
Sample 10	8203	First Draw	Tap	Room 147	9	5/29/2018	
Sample 11	8204	First Draw	Tap	Room 146	5	5/29/2018	