



Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please note: The school has replaced all fixtures with detectable lead and replaced those with lead free certified fixtures. The school is participating in follow up testing to reduce children's overall exposure to lead.

**School District:** Eatonville

**School Name:** Columbia Crest A-STEM Academy

**School Code:** 2808

**School Address:** 24503 State Route 706 E, Ashford Washington 98304

**Number of Samples Collected:** 19

**Date Collected:** 11/28/2018

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
16961	other	other		<1	12/12/2018	06277, 7:20 AM
16962	FirstDraw	Tap	Kitchen	34	12/12/2018	Food Prep Sink Near laundry room
16963	FirstDraw	Bubbler	Across from Room 108	<1	12/12/2018	
16964	FirstDraw	Bubbler	Room 112	6	12/12/2018	
16965	FirstDraw	Tap	Room 112	16	12/12/2018	
16966	FirstDraw	Tap	Room 111	11	12/12/2018	
16967	FirstDraw	Tap	Room 110	5	01/15/2019	
16968	FirstDraw	Tap	Room 109	10	12/12/2018	
16969	FirstDraw	Bubbler	Room 107	29	12/12/2018	Left Side Sink
16970	FirstDraw	Tap	Room 107	19	12/12/2018	Left Side Sink
16971	FirstDraw	Tap	Room 107	38	01/15/2019	Right Side Sink
16972	FirstDraw	BottleFiller	Near Front Office	1	12/12/2018	
16973	FirstDraw	Tap	Health Office	34	12/12/2018	
16974	FirstDraw	Bubbler	Room 108	8	12/12/2018	
16975	FirstDraw	Tap	Room 108	18	12/12/2018	
16976	FirstDraw	Tap	Sunrise P-1	8	12/12/2018	Sink Nearest Door
16977	FirstDraw	Bubbler	Sunrise P-1	13	12/12/2018	2nd sink from door
16978	FirstDraw	Tap	Sunrise P-1	8	12/12/2018	2nd sink from door
16979	FirstDraw	Tap	Sunrise P-1	6	12/12/2018	Sink near window