



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District: Wapato
School Name: Simcoe Elementary School
Date Collected: 06/13/2019
School Code: NA
School Address: 1307 South Camas Ave, Wapato WA 98951
School County: Yakima
Number of Samples Collected: 51

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1	20657	First Draw	Bubbler	Rm 406	<1	7/12/2019	
2	26008	First Draw	Pot Filler	Kitchen	5	7/25/2019	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
3	26009	First Draw	Tap	Kitchen	<1	7/11/2019	Island Behind ovens
4	26010	First Draw	Bubbler	Cafeteria	<1	7/11/2019	
5	26011	First Draw	Bubbler	Cafeteria	<1	7/11/2019	
6	26012	First Draw	Bottle Filler	Cafeteria	<1	7/11/2019	
7	26013	First Draw	Bubbler	Rm 309	<1	7/12/2019	
8	26014	First Draw	Tap	Rm 309	<1	7/12/2019	
9	26015	First Draw	Bubbler	Rm 502	<1	7/12/2019	
10	26016	First Draw	Tap	Rm 502	<1	7/12/2019	
11	26017	First Draw	Bubbler	Rm 503	<1	7/12/2019	
12	26018	First Draw	Tap	Rm 503	1	7/12/2019	
13	26019	First Draw	Bubbler	Rm 504	2	7/12/2019	
14	26020	First Draw	Tap	Rm 504	<1	7/12/2019	
15	26021	First Draw	Bubbler	Rm 505	<1	7/12/2019	
16	26022	First Draw	Tap	Rm 505	<1	7/12/2019	
17	26023	First Draw	Bubbler	Rm 509	2	7/12/2019	
18	26024	First Draw	Tap	Rm 509	<1	7/12/2019	
19	26025	First Draw	Bubbler	Rm 512	<1	7/12/2019	
20	26026	First Draw	Tap	Rm 512	<1	7/12/2019	
21	26027	First Draw	Bubbler	Rm 511	<1	7/12/2019	
22	26028	First Draw	Tap	Rm 511	<1	7/12/2019	
23	26029	First Draw	Bubbler	Rm 510	<1	7/12/2019	
24	26030	First Draw	Tap	Rm 510	<1	7/12/2019	
25	26031	First Draw	Bubbler	Next to 609	<1	7/12/2019	Left

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
26	26032	First Draw	Bubbler	Next to 609	<1	7/12/2019	Right
27	26033	First Draw	Bubbler	Rm 619	<1	7/12/2019	
28	26034	First Draw	Tap	Rm 619	<1	7/12/2019	
29	26035	First Draw	Bubbler	Rm 620	1	7/12/2019	
30	26036	First Draw	Tap	Rm 620	<1	7/12/2019	
31	26037	First Draw	Bubbler	Rm 621	3	7/25/2019	
32	26038	other	Tap	Rm 621	<1	7/12/2019	
33	26039	First Draw	Bubbler	Rm 623	<1	7/12/2019	
34	26040	First Draw	Tap	Rm 623	<1	7/12/2019	
35	26041	First Draw	Bubbler	Rm 703	4	7/12/2019	
36	26042	First Draw	Tap	Rm 703	1	7/12/2019	
37	26043	First Draw	Bubbler	Rm 707	<1	7/12/2019	
38	26044	First Draw	Tap	Rm 707	<1	7/12/2019	
39	26045	First Draw	Bubbler	Rm 711	<1	7/12/2019	
40	26046	First Draw	Tap	Rm 711	<1	7/12/2019	
41	26047	First Draw	Bubbler	Rm 710	<1	7/12/2019	
42	26048	First Draw	Tap	Rm 710	<1	7/12/2019	
43	26049	First Draw	Bubbler	Rm 706	<1	7/12/2019	
44	26050	First Draw	Tap	Rm 706	<1	7/12/2019	
45	26051	First Draw	Bubbler	Rm 705	<1	7/12/2019	
46	26053	First Draw	Bubbler	Rm 709	<1	7/12/2019	
47	26054	First Draw	Tap	Rm 709	<1	7/12/2019	
48	26055	First Draw	Bubbler	Rm 706	<1	7/12/2019	
49	26056	First Draw	Tap	Rm 706	2	7/12/2019	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
50	26058	First Draw	Tap	Rm 406	<1	7/12/2019	