



Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following all recommended remediation to help reduce children's exposure to lead in drinking water.

**School District:** Kelso

**School Name:** Beacon Hill Elementary School

**School Code:** 3578

**School Address:** 257 Alpha Dr, Longview Washington 98632

**Number of Samples Collected:** 8

**Date Collected:** 06/07/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
25684	FirstDraw	Tap	Kitchen	11	06/24/2019	Single tap
25685	FirstDraw	Tap	Rms. 1-4 shares sink	TB	NA	
25686	FirstDraw	Tap	Quad 3	31	06/24/2019	
25687	FirstDraw	Tap	Rm 11	13	06/24/2019	
25688	FirstDraw	Tap	Rm 20	21	06/24/2019	
25689	FirstDraw	Tap	Rm 19	19	06/24/2019	
25690	FirstDraw	Bubbler	Portable 28	<1	06/24/2019	
25691	other			<1	06/24/2019	