



Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

**School District:** Bethel

**School Name:** Naches Trail Elementary

**School Code:** 4102

**School Address:** 15305 Waller Road E, Tacoma Washington 98446

**Number of Samples Collected:** 2

**Date Collected:** 11/30/2018

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
17030	FirstDraw	Bubbler	Room 1	17	12/07/2018	7:30 AM 2 months of flushing 3x a day
17031	other	other		<1	12/07/2018	06290