



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school district is following all recommended remediation to help reduce children's overall exposure to lead in drinking water.

School District: Ferndale

School Name: Discovery Center (Mt View Campus)

School Code: NA

School Address: 5780 Hendrickson Road, Ferndale Washington 98248

Number of Samples Collected: 28

Date Collected: 10/02/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
25888	other	other		<1	10/03/2019	7:14 AM, 10882
25889	FirstDraw	Tap	Mr. Bob's Room	1	10/03/2019	used this morning
25890	FirstDraw	Bubbler	Room 3	9	10/03/2019	
25891	FirstDraw	Tap	Room 3	2	10/03/2019	
25892	FirstDraw	Bubbler	Between Restrooms across from Room 3	2	10/03/2019	
25893	FirstDraw	Bubbler	Room 4	7	10/04/2019	
25894	FirstDraw	Tap	Room 4	2	10/03/2019	
25895	FirstDraw	Tap	Health Room	2	10/04/2019	
25896	FirstDraw	Tap	Staff Lounge	<1	10/04/2019	
25897	FirstDraw	Tap	Room 6	10	10/04/2019	bubbler off, tap may not be in use
25898	FirstDraw	Bubbler	Room 8	15	10/04/2019	
25899	FirstDraw	Tap	Room 8	11	10/04/2019	dripping
25900	FirstDraw	Bubbler	Room 7	16	10/04/2019	
26337	FirstDraw	Tap	Room 7	9	10/04/2019	
26338	FirstDraw	Bubbler	Room 10	8	10/04/2019	
26339	FirstDraw	Tap	Room 10	3	10/04/2019	
26340	FirstDraw	Bubbler	Room 12	5	10/04/2019	
26341	FirstDraw	Tap	Room 12	1	10/04/2019	
26342	FirstDraw	Bubbler	Room 11	12	10/04/2019	
26343	FirstDraw	Tap	Room 11	3	10/04/2019	
26344	FirstDraw	Bubbler	Room 9	8	10/04/2019	
26345	FirstDraw	Tap	Room 9	2	10/04/2019	
26346	FirstDraw	Tap	Kitchen	30	10/04/2019	
26347	FirstDraw	Tap	Library Conference Room	6	10/04/2019	
26348	FirstDraw	Tap	Room G	237	10/04/2019	bubbler turned off

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
26349	FirstDraw	Bubbler	Room F	72	10/04/2019	Mineral deposits on bubbler
26350	FirstDraw	Tap	Room F	31	10/04/2019	
26351	FirstDraw	Bubbler	Left Bubbler Near Restrooms	53	10/04/2019	Right bubbler turned off