



### **Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**School District Name: Mead School District**

**School Name: Brentwood Elementary School**

**School Code: 3693**

**Address: 406 W. Regina Ave Spokane WA 99218**

**Number of Samples Collected: 65**

**Date Collected: 6/6/2018**

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	10128	BLANK	BLANK	BLANK	<1	7/5/2018	
Sample 2	10129	First Draw	Tap	Kitchen	1	7/5/2018	Big Sink, Left Tap
Sample 3	10130	First Draw	Tap	Kitchen	5	7/5/2018	Big Sink, Right Tap
Sample 4	10131	First Draw	Tap	Kitchen	4	7/5/2018	Handwashing Sink. Middle Island
Sample 5	10132	First Draw	Tap	Kitchen	<1	7/5/2018	Handwashing Sink Near Bathroom
Sample 6	10133	First Draw	Pot Filler	Kitchen	TB	7/5/2018	Near Bathroom
Sample 7	10134	First Draw	Bubbler	Gym	2	7/5/2018	
Sample 8	10135	First Draw	Tap	Room 2	TB	7/5/2018	
Sample 9	10136	First Draw	Bubbler	Room 2	6	7/5/2018	
Sample 10	10137	First Draw	Tap	Room 4	TB	7/5/2018	
Sample 11	10138	First Draw	Bubbler	Room 4	2	7/5/2018	
Sample 12	10139	First Draw	Bubbler	Near Room 6	<1	7/5/2018	
Sample 13	10140	First Draw	Bubbler	Room 6	3	7/5/2018	
Sample 14	10141	First Draw	Tap	Room 6	3	7/5/2018	
Sample 15	10142	First Draw	Bubbler	Room 8	6	7/5/2018	
Sample 16	10143	First Draw	Tap	Room 8	5	7/5/2018	
Sample 17	10144	First Draw	Bubbler	Room 1	4	7/5/2018	
Sample 18	10145	First Draw	Tap	Room 1	12	7/5/2018	
Sample 19	10146	First Draw	Bubbler	Room 10	5	7/5/2018	
Sample 20	10147	First Draw	Tap	Room 10	7	7/5/2018	
Sample 21	10148	First Draw	Bubbler	Room 0	4	7/5/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 22	10149	First Draw	Tap	Room 0	9	7/5/2018	
Sample 23	10150	First Draw	Bubbler	Room 9	4	7/5/2018	
Sample 24	10151	First Draw	Tap	Room 9	6	7/5/2018	
Sample 25	10152	First Draw	Bubbler	Room 7	3	7/5/2018	
Sample 26	10153	First Draw	Tap	Room 7	14	7/5/2018	
Sample 27	10154	First Draw	Bubbler	Room 5	2	7/5/2018	
Sample 28	10155	First Draw	Tap	Room 5	6	7/5/2018	
Sample 29	10156	First Draw	Bubbler	Near Room 5	<1	7/5/2018	
Sample 30	10157	First Draw	Tap	Room 3	5	7/5/2018	
Sample 31	10158	First Draw	Bubbler	Room 3	2	7/5/2018	
Sample 32	10159	First Draw	Tap	Clinic	2	7/5/2018	
Sample 33	10160	First Draw	Bubbler	Room 22	4	7/5/2018	
Sample 34	10161	First Draw	Tap	Room 22	6	7/5/2018	
Sample 35	10162	First Draw	Bubbler	Room 23	6	7/5/2018	
Sample 36	10163	First Draw	Tap	Room 23	7	7/5/2018	
Sample 37	10164	First Draw	Bubbler	Near Room 23	2	7/5/2018	
Sample 38	10165	First Draw	Tap	Room 20	4	7/5/2018	
Sample 39	10166	First Draw	Bubbler	Room 20	3	7/5/2018	
Sample 40	10167	First Draw	Tap	Room 21	4	7/5/2018	
Sample 41	10168	First Draw	Bubbler	Room 21	3	7/5/2018	
Sample 42	10169	First Draw	Tap	Room 18	6	7/5/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 43	10170	First Draw	Bubbler	Room 18	3	7/5/2018	
Sample 44	10171	First Draw	Tap	Room 19	9	7/5/2018	
Sample 45	10172	First Draw	Bubbler	Room 19	2	7/5/2018	
Sample 46	10173	First Draw	Tap	Room 16	5	7/5/2018	
Sample 47	10174	First Draw	Bubbler	Room 16	1	7/5/2018	
Sample 48	10175	First Draw	Tap	Room 17	7	7/5/2018	
Sample 49	10176	First Draw	Bubbler	Room 17	1	7/5/2018	
Sample 50	10177	First Draw	Bubbler	Near Room 17	1	7/5/2018	
Sample 51	10178	First Draw	Bubbler	Room 14	1	7/5/2018	
Sample 52	10179	First Draw	Tap	Room 14	8	7/5/2018	
Sample 53	10180	First Draw	Bubbler	Room 15	2	7/5/2018	
Sample 54	10181	First Draw	Tap	Room 15	6	7/5/2018	
Sample 55	10182	First Draw	Bubbler	Room 12	<1	7/5/2018	
Sample 56	10183	First Draw	Tap	Room 12	14	7/5/2018	
Sample 57	10184	First Draw	Bubbler	Near School Counselor Office	<1	7/5/2018	
Sample 58	10185	First Draw	Bottle Filler	Near School Counselor Office	<1	7/5/2018	
Sample 59	10186	First Draw	Bubbler	Near Custodial Office	<1	7/5/2018	Left Bubbler
Sample 60	10187	First Draw	Bubbler	Near Custodial Office	<1	7/5/2018	Right Bubbler
Sample 61	10188	First Draw	Bubbler	Room 42	<1	7/5/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 62	10189	First Draw	Tap	Room 42	<1	7/5/2018	
Sample 63	10190	First Draw	Tap	Room 215	<1	7/5/2018	
Sample 64	10191	First Draw	Tap	Room 214	<1	7/6/2018	
Sample 65	10192	First Draw	Tap	Room 401	<1	7/6/2018	
Sample 66	10193	First Draw	Tap	Room 400	<1	7/6/2018	

TB= Turbidity, further analysis required.