



Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following recommended remediation to help reduce children's exposure to lead in drinking water.

**School District:** Chewelah

**School Name:** Jenkins Junior Senior High School

**School Code:** 2404

**School Address:** East 703 Lincoln, Chewelah Washington 99109

**Number of Samples Collected:** 20

**Date Collected:** 11/14/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
29600	FirstDraw	Tap	Rm 7 Science room	1	11/25/2019	Tap 3 Right of exit door
29595	other	other		<1	11/25/2019	Taken in hallway
29596	FirstDraw	Bubbler	Entrance hallway	<1	11/25/2019	Hydration station
29597	FirstDraw	BottleFiller	Entrance hallway	<1	11/25/2019	Hydration station
29598	FirstDraw	Tap	Staff room	1	11/25/2019	
29599	FirstDraw	Tap	Kitchen	<1	11/25/2019	Only 1 sink
29600	FirstDraw	Tap	Rm 15 unisex bathroom	1	11/25/2019	Kids fill water bottles portable room
29601	FirstDraw	Tap	Rm 16	2	11/25/2019	Portable classroom students fill water bottles
29602	FirstDraw	Tap	Art room	7	11/25/2019	
29603	FirstDraw	Tap	Room 10	4	11/25/2019	Special ed room
29604	FirstDraw	Tap	Room 8	6	11/25/2019	Science room sink to right of stove. Food prep sink
29605	FirstDraw	Tap	Room 7 Science room	4	11/25/2019	Tap 1 Sink that is used for coffee
29606	FirstDraw	Tap	Rm 7 science room	3	11/25/2019	Tap 2 Next to exit door
29608	FirstDraw	Tap	Rm 7 science room	8	11/26/2019	Tap 4 next to tank
29609	FirstDraw	Bubbler	Main hallway	<1	11/25/2019	Hydration station.
29610	FirstDraw	BottleFiller	Main hallway	<1	11/25/2019	Hydration station

*(continued)*

<b>Program ID</b>	<b>Sample Type</b>	<b>Description</b>	<b>Location</b>	<b>Lead Results (ppb)</b>	<b>Analysis Date</b>	<b>Comments</b>
29611	FirstDraw	Bubbler	Main hallway near exit	1	11/25/2019	Drinking fountain
29612	FirstDraw	Bubbler	Upstairs weight room	<1	11/25/2019	Drinking fountain
29613	FirstDraw	Bubbler	Vo Tech Room	<1	11/25/2019	Hydration station
29614	FirstDraw	BottleFiller	Vo Tech Room	<1	11/25/2019	Hydration station