



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Federal Way

School Name: Brigadoon Elementary

School Code: 3700

Address: 3601 SW 336th St Federal Way 98023

County: King

Number of Samples Collected: 51

Date Collected: 3/22/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	5338	First Draw	Tap	Health Room	18	06/05/2018	Some cleaner sprayed around sink, bubbler doesn't work
Sample 2	5339	First Draw	Tap	Staff Room	<1	06/05/2018	
Sample 3	5340	First Draw	Hot Tap	Staff Room	<1	06/05/2018	
Sample 4	5341	First Draw	Water Cooler	Staff Room	<1	06/05/2018	
Sample 5	5342	First Draw	Tap	Room 31	5	06/05/2018	
Sample 6	5343	First Draw	Bubbler	Room 31	3	06/05/2018	
Sample 7	5344	First Draw	Tap	Room 33, Kitchen	1	06/05/2018	Water bubbly in bottle
Sample 8	5345	First Draw	Drinking Fountain	Between Rooms 32 & 33	6	06/05/2018	Type: HAWS
Sample 9	5346	First Draw	Tap	Room 32	4	06/05/2018	Faucet and bubbler turned off in Room 30
Sample 10	5347	First Draw	Drinking Fountain	Gym	1	06/05/2018	High pressure
Sample 11	5348	First Draw	Tap	Room 20	5	06/05/2018	Faucet is a little loose
Sample 12	5349	First Draw	Bubbler	Room 20	6	06/05/2018	High pressure
Sample 13	5350	First Draw	Tap	Room 22	1	06/05/2018	
Sample 14	5351	First Draw	Bubbler	Room 22	2	06/05/2018	
Sample 15	5352	First Draw	Tap	Room 24	12	06/05/2018	
Sample 16	5353	First Draw	Bubbler	Room 24	8	06/05/2018	Sample taken after dribbling down mouth of bubbler
Sample 17	5354	First Draw	Tap	Room 25	2	06/05/2018	
Sample 18	5355	First Draw	Bubbler	Room 25	3	06/05/2018	High pressure

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 19	5356	First Draw	Tap	Room 23	2	06/05/2018	
Sample 20	5357	First Draw	Bubbler	Room 23	3	06/05/2018	High pressure
Sample 21	5358	First Draw	Tap	Room 21	11	06/05/2018	
Sample 22	5359	First Draw	Tap	Room 52	7	06/05/2018	Left Dispenser
Sample 23	5360	First Draw	Tap	Room 54	33	06/05/2018	Right Dispenser
Sample 24	5361	First Draw	Bubbler	Room 54	7	06/05/2018	
Sample 25	5362	First Draw	Tap	Room 56	6	06/05/2018	
Sample 26	5363	First Draw	Bubbler	Room 56	7	06/05/2018	
Sample 27	5364	First Draw	Tap	Room 55	4	06/05/2018	Used by staff member
Sample 28	5365	First Draw	Bubbler	Room 55	6	06/05/2018	
Sample 29	5366	First Draw	Tap	Room 53	3	06/05/2018	
Sample 30	5367	First Draw	Bubbler	Room 53	3	06/05/2018	
Sample 31	5368	First Draw	Tap	Room 51	1	06/05/2018	
Sample 32	5369	First Draw	Bubbler	Room 51	1	06/05/2018	
Sample 33	5370	First Draw	Tap	Room 50	5	06/05/2018	No Aerator
Sample 34	5371	First Draw	Tap	Room 57	7	06/05/2018	
Sample 35	5372	First Draw	Bubbler	Room 57	6	06/05/2018	
Sample 36	5373	First Draw	Tap	Room 58	24	06/05/2018	
Sample 37	5374	First Draw	Bubbler	Room 58	15	06/05/2018	
Sample 38	5375	First Draw	Tap	Library Sink	9	06/05/2018	Yellowy water, according to staff member
Sample 39	5376	First Draw	Tap	Room 40	54	8/6/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 40	5377	First Draw	Bubbler	Room 40	33	06/05/2018	
Sample 41	5378	First Draw	Tap	Room 42	26	06/05/2018	
Sample 42	5379	First Draw	Bubbler	Room 42	11	06/05/2018	
Sample 43	5380	First Draw	Tap	Room 43	10	06/05/2018	
Sample 44	5381	First Draw	Bubbler	Room 43	11	06/05/2018	High pressure
Sample 45	5382	First Draw	Tap	Room 41	5	06/05/2018	
Sample 46	5383	First Draw	Bubbler	Room 41	7	06/05/2018	High pressure
Sample 47	5384	First Draw	Tap	Room 35	14	06/05/2018	
Sample 48	5385	First Draw	Bubbler	Room 35	2	06/05/2018	High pressure
Sample 49	5386	First Draw	Tap	Between Rooms 34 & 35	1	06/05/2018	Used by staff
Sample 50	5387	First Draw	Tap	Room 34	4	06/05/2018	
Sample 51	5388	First Draw	Bubbler	Room 34	4	06/05/2018	High pressure
Sample 52	5389	Blank	Blank	Room 23	<1	06/05/2018	05790