



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Prosser School District

School Name: Keene-Riverview Elementary School

School Code: 2195

Address: 823 Park Ave Prosser WA 99350

Number of Samples Collected: 45

Date Collected: 3/20/2018

| Sample number | Sample ID | Sample Type | Fixture Description | Fixture Location | Lead Content (ppb) | Date of Analysis | Notes/Comments |
|---------------|-----------|-------------|---------------------|----------------------------|--------------------|------------------|----------------|
| Sample 1 | 3012 | First Draw | Bubbler | Room 2 | 2 | 6/19/2018 | |
| Sample 2 | 3013 | First Draw | Tap | Room 2 | 2 | 6/19/2018 | |
| Sample 3 | 3014 | First Draw | Bubbler | Library | <1 | 6/19/2018 | |
| Sample 4 | 3015 | First Draw | Tap | Library | <1 | 6/19/2018 | |
| Sample 5 | 3016 | First Draw | Bubbler | Room 1 | 2 | 6/19/2018 | |
| Sample 6 | 3017 | First Draw | Tap | Room 1 | 1 | 6/19/2018 | |
| Sample 7 | 3018 | First Draw | Bubbler | Outside multi purpose room | 1 | 6/19/2018 | |
| Sample 8 | 3019 | First Draw | Bubbler | Nurse Station | 1 | 6/19/2018 | |
| Sample 9 | 3020 | First Draw | Tap | Nurse Station | 3 | 6/19/2018 | |
| Sample 10 | 3021 | First Draw | Bubbler | Outside Nurse Station | 1 | 6/19/2018 | |
| Sample 11 | 3022 | First Draw | Bubbler | room 9 | 2 | 6/19/2018 | |
| Sample 12 | 3023 | First Draw | Tap | room 9 | <1 | 6/19/2018 | |
| Sample 13 | 3024 | First Draw | Bubbler | Room 8 | 2 | 6/19/2018 | |
| Sample 14 | 3025 | First Draw | Tap | Room 8 | 1 | 6/19/2018 | |
| Sample 15 | 3026 | First Draw | Bubbler | Room 7 | 2 | 6/19/2018 | High pressure |
| Sample 16 | 3027 | First Draw | Tap | Room 7 | 2 | 6/19/2018 | |
| Sample 17 | 3028 | First Draw | Bubbler | Near room 7 near bathroom | <1 | 6/19/2018 | |
| Sample 18 | 3029 | First Draw | Tap | Room 12 | 1 | 6/19/2018 | |
| Sample 19 | 3030 | First Draw | Bubbler | Room 12 | 4 | 6/19/2018 | |
| Sample 20 | 3031 | First Draw | Bubbler | Outside 13 | 1 | 6/19/2018 | |

| Sample number | Sample ID | Sample Type | Fixture Description | Fixture Location | Lead Content (ppb) | Date of Analysis | Notes/Comments |
|---------------|-----------|-------------|---------------------|------------------|--------------------|------------------|----------------|
| Sample 21 | 3032 | First Draw | Bubbler | Room 13 | 3 | 6/19/2018 | |
| Sample 22 | 3033 | First Draw | Tap | Room 13 | <1 | 6/19/2018 | |
| Sample 23 | 3034 | First Draw | Bubbler | Room 14 | 2 | 6/19/2018 | |
| Sample 24 | 3035 | First Draw | Tap | Room 14 | 1 | 6/19/2018 | |
| Sample 25 | 3036 | First Draw | Bubbler | Castillo | 3 | 6/19/2018 | |
| Sample 26 | 3037 | First Draw | Tap | Castillo | 1 | 6/19/2018 | |
| Sample 27 | 3038 | First Draw | Bubbler | Room 17 | 4 | 6/19/2018 | |
| Sample 28 | 3039 | First Draw | Tap | Room 17 | 2 | 6/19/2018 | |
| Sample 29 | 3040 | First Draw | Bubbler | Room 20 | 7 | 6/19/2018 | |
| Sample 30 | 3041 | First Draw | Tap | Room 20 | 2 | 6/19/2018 | |
| Sample 31 | 3042 | First Draw | Bubbler | Outside room 20 | <1 | 6/19/2018 | |
| Sample 32 | 3043 | First Draw | Bubbler | Room 22 | 1 | 6/19/2018 | |
| Sample 33 | 3044 | First Draw | Tap | Room 22 | <1 | 6/19/2018 | |
| Sample 34 | 3045 | First Draw | Tap | Room 23 | 3 | 6/19/2018 | |
| Sample 35 | 3046 | First Draw | Bubbler | Room 23 | 5 | 6/19/2018 | |
| Sample 36 | 3047 | First Draw | BLANK | BLANK | <1 | 6/19/2018 | |
| Sample 37 | 3048 | First Draw | Tap | Room 24 | 1 | 6/19/2018 | |
| Sample 38 | 3049 | First Draw | Tap | Room 25 | <1 | 6/19/2018 | |
| Sample 39 | 3050 | First Draw | Bubbler | Room 25 | 1 | 6/19/2018 | |
| Sample 40 | 3051 | First Draw | Tap | Room 26 | <1 | 6/19/2018 | |
| Sample 41 | 3052 | First Draw | Bubbler | Room 26 | 1 | 6/19/2018 | |
| Sample 42 | 3053 | First Draw | Tap | Room 27 | <1 | 6/19/2018 | |

| Sample number | Sample ID | Sample Type | Fixture Description | Fixture Location | Lead Content (ppb) | Date of Analysis | Notes/Comments |
|---------------|-----------|-------------|---------------------|------------------|--------------------|------------------|----------------|
| Sample 43 | 3054 | First Draw | Tap | Portable 32 | <1 | 6/19/2018 | |
| Sample 44 | 3055 | First Draw | Tap | Kitchen | <1 | 6/19/2018 | |
| Sample 45 | 3056 | First Draw | Tap | Kitchen | 2 | 6/19/2018 | Near Fridges |