



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District: Renton

School Name: Risdon Middle School

School Code: 5484

School Address: 6928 116th Ave SE, Newcastle Washington 98056

Number of Samples Collected: 81

Date Collected: 05/21/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
24264	other			<1	06/17/2019	
24265	FirstDraw	Tap	Kitchen	<1	06/17/2019	Double sink next to pot filler, left
24266	FirstDraw	Tap	Kitchen	1	06/17/2019	Double sink next to pot filler, right
24267	FirstDraw	PotFiller	Kitchen	TB	NA	
24268	FirstDraw	Tap	Rm 237	<1	06/17/2019	
24269	FirstDraw	Tap	Rm 238	<1	06/17/2019	
24270	FirstDraw	Bubbler	Next to Rm 238	<1	06/17/2019	Left
24271	FirstDraw	Bubbler	Next to Rm 238	<1	06/17/2019	Right
24272	FirstDraw	BottleFiller	Next to Rm 238	<1	06/17/2019	
24273	FirstDraw	Tap	Rm 236	<1	06/17/2019	
24274	FirstDraw	Tap	Rm 235	2	06/17/2019	
24275	FirstDraw	Tap	Rm 239	1	06/17/2019	
24276	FirstDraw	Tap	Rm 240	1	06/17/2019	
24277	FirstDraw	Tap	Rm 234	<1	06/17/2019	
24278	FirstDraw	Tap	Rm 233	<1	06/17/2019	
24279	FirstDraw	Tap	Rm 232	<1	06/17/2019	
24280	FirstDraw	Tap	Rm 210	<1	06/17/2019	
24281	FirstDraw	Tap	Rm 209	<1	06/17/2019	
24282	FirstDraw	Tap	Rm 208	1	06/17/2019	
24283	FirstDraw	Tap	Rm 205	2	06/17/2019	
24284	FirstDraw	Tap	Rm 206	3	06/17/2019	
24285	FirstDraw	Tap	Rm 203	1	06/17/2019	
24286	FirstDraw	Tap	Rm 202	<1	06/17/2019	
24287	FirstDraw	Bubbler	Across from 216	<1	06/17/2019	Left
24288	FirstDraw	Bubbler	Across from 216	<1	06/17/2019	Right
24289	FirstDraw	BottleFiller	Across from 216	<1	06/17/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
24290	FirstDraw	Bubbler	Across from 264	<1	06/17/2019	Left
24291	FirstDraw	Bubbler	Across from 264	<1	06/17/2019	Right
24292	FirstDraw	BottleFiller	Across from 264	<1	06/17/2019	
24293	FirstDraw	Tap	Rm 263	1	06/17/2019	
24294	FirstDraw	Tap	Rm 262	<1	06/17/2019	
24295	FirstDraw	Tap	Rm 261	<1	06/17/2019	
24296	FirstDraw	Tap	Rm 260	<1	06/17/2019	
24297	FirstDraw	Tap	Rm 257	<1	06/17/2019	
24298	FirstDraw	Tap	Rm 256	<1	06/17/2019	
24299	FirstDraw	Tap	Rm 255	<1	06/17/2019	
24300	FirstDraw	Tap	Rm 254	<1	06/17/2019	
24301	FirstDraw	Tap	Rm 253	<1	06/17/2019	
24302	FirstDraw	Tap	Rm 186	<1	06/17/2019	1
24303	FirstDraw	Tap	Rm 186	<1	06/17/2019	2
24304	FirstDraw	Tap	Rm 186	<1	06/17/2019	3
24305	FirstDraw	Tap	Rm 186	<1	06/17/2019	4
24306	FirstDraw	Tap	Rm 186	<1	06/17/2019	5
24307	FirstDraw	Tap	Rm 186	<1	06/17/2019	6
24308	FirstDraw	Tap	Rm 186	<1	06/17/2019	7
24309	FirstDraw	Tap	Rm 186	<1	06/17/2019	8
24310	FirstDraw	Bubbler	Rm 191	<1	06/17/2019	Left
24311	FirstDraw	Bubbler	Rm 191	<1	06/17/2019	Right
24312	FirstDraw	BottleFiller	Rm 191	<1	06/17/2019	
24313	FirstDraw	Bubbler	Outside Boys Locker Room	<1	06/17/2019	Left
24314	FirstDraw	Bubbler	Outside Boys Locker Room	<1	06/17/2019	Right
24315	FirstDraw	BottleFiller	Outside Boys Locker Room	<1	06/17/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
24316	FirstDraw	Tap	Nurse	<1	06/17/2019	
24317	FirstDraw	Tap	Office workroom	<1	06/17/2019	
24318	FirstDraw	Tap	Rm 130	1	06/17/2019	
24319	FirstDraw	Tap	Rm 132	<1	06/17/2019	
24320	FirstDraw	Tap	Rm 160	<1	06/17/2019	
24321	FirstDraw	Tap	Rm 161	<1	06/17/2019	
24322	FirstDraw	Tap	Rm 162	<1	06/17/2019	
24323	FirstDraw	Tap	Rm 163	<1	06/17/2019	
24324	FirstDraw	Tap	Rm 164	<1	06/17/2019	
24325	FirstDraw	Tap	Rm 166	1	06/17/2019	
24326	FirstDraw	Tap	Rm 165	<1	06/17/2019	
24328	FirstDraw	Bubbler	Next to 166	<1	06/17/2019	Left
24329	FirstDraw	Bubbler	Next to 166	<1	06/17/2019	Right
24330	FirstDraw	BottleFiller	Next to 166	<1	06/17/2019	
24331	FirstDraw	Tap	Rm 167	<1	06/17/2019	
24332	FirstDraw	Tap	Rm 168	<1	06/17/2019	
24333	FirstDraw	Bubbler	Outside music room	<1	06/17/2019	Left
24334	FirstDraw	Bubbler	Outside music room	<1	06/17/2019	Right
24335	FirstDraw	BottleFiller	Outside music room	<1	06/17/2019	
24336	FirstDraw	Bubbler	Rm 147	<1	06/17/2019	Bubbler only
24337	FirstDraw	Tap	Rm 138	<1	06/17/2019	
24338	FirstDraw	Bubbler	Main gym entrance	<1	06/17/2019	Left side left bubbler
24339	FirstDraw	Bubbler	Main gym entrance	<1	06/17/2019	Left side right bubbler
24340	FirstDraw	BottleFiller	Main gym entrance	<1	06/17/2019	Left side
24341	FirstDraw	Bubbler	Main gym entrance	<1	06/17/2019	Right side right bubbler
24342	FirstDraw	Bubbler	Main gym entrance	<1	06/17/2019	Right side right bubbler

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
24343	FirstDraw	BottleFiller	Main gym entrance	<1	06/17/2019	Right side
24344	FirstDraw	Tap	Cafeteria by vending machine	<1	06/17/2019	
24345	FirstDraw	Tap	Custodian Office	<1	06/17/2019	