



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please note: The school has since notified the Department of Health that all fixtures higher than 1ppb were replaced.

School District Name: Cheney School District

School Name: Betz Elementary School

School Code: 2954

Address: 317 N. 7th Cheney WA 99004

County: Spokane

Number of Samples Collected: 73

Date Collected: 4/26/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	4259		BLANK	BLANK	<1	5/23/2018	
Sample 2	4260	First Draw	Tap	Clinic	2	5/23/2018	
Sample 3	4261	First Draw	Tap	Main Kitchen	3	5/23/2018	Main Sink by the Entrance. Left Tap
Sample 4	4262	First Draw	Tap	Main Kitchen	4	5/23/2018	Main Sink by the Entrance. Right Tap
Sample 5	4263	First Draw	Tap	Main Kitchen	2	5/23/2018	Side Wall Near the Bathroom
Sample 6	4264	First Draw	Tap	Main Kitchen	1	5/23/2018	Personal Handwashing Sink near the Front of the Kitchen
Sample 7	4265	First Draw	Tap	Community Kitchen	1	5/23/2018	
Sample 8	4266	First Draw	Tap	Room 201	4	5/23/2018	
Sample 9	4267	First Draw	Bubbler	Room 201	2	5/23/2018	
Sample 10	4268	First Draw	Tap	Portable C1	1	5/23/2018	
Sample 11	4269	First Draw	Bubbler	Portable C1	<1	5/23/2018	
Sample 12	4270	First Draw	Tap	Portable C2	1	5/23/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 13	4271	First Draw	Bubbler	Portable C2	<1	5/23/2018	
Sample 14	4272	First Draw	Tap	Portable B1	5	5/23/2018	
Sample 15	4273	First Draw	Bubbler	Portable B1	1	5/23/2018	
Sample 16	4274	First Draw	Tap	Portable B2	3	5/23/2018	
Sample 17	4275	First Draw	Bubbler	Portable B2	2	5/23/2018	
Sample 18	4276	First Draw	Tap	Portable C1	3	5/23/2018	
Sample 19	4277	First Draw	Bubbler	Portable C1	5	5/23/2018	
Sample 20	4278	First Draw	Tap	Portable C2	1	5/23/2018	
Sample 21	4279	First Draw	Bubbler	Portable C2	<1	5/23/2018	
Sample 22	4280	First Draw	Tap	Room 211	3	5/23/2018	
Sample 23	4281	First Draw	Bubbler	Room 211	1	5/23/2018	
Sample 24	4282	First Draw	Tap	Room 210	1	5/23/2018	
Sample 25	4283	First Draw	Bubbler	Room 210	<1	5/23/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 26	4284	First Draw	Tap	Room 208	2	5/23/2018	
Sample 27	4285	First Draw	Bubbler	Room 208	<1	5/23/2018	
Sample 28	4286	First Draw	Tap	Room 209	3	5/23/2018	
Sample 29	4287	First Draw	Bubbler	Room 209	<1	5/23/2018	
Sample 30	4288	First Draw	Tap	Room 207	1	5/23/2018	
Sample 31	4289	First Draw	Bubbler	Room 207	<1	5/23/2018	
Sample 32	4290	First Draw	Tap	Room 206	2	5/23/2018	
Sample 33	4291	First Draw	Bubbler	Room 206	<1	5/23/2018	
Sample 34	4292	First Draw	Tap	Room 204	2	5/23/2018	
Sample 35	4293	First Draw	Bubbler	Room 204	<1	5/23/2018	
Sample 36	4294	First Draw	Tap	Room 203	2	5/23/2018	
Sample 37	4295	First Draw	Bubbler	Room 203	2	5/23/2018	
Sample 38	4296	First Draw	Tap	Room 202	5	5/23/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 39	4297	First Draw	Bubbler	Room 202	1	5/23/2018	
Sample 40	4298	First Draw	Bubbler	Near Room 106 (Library)	1	5/23/2018	
Sample 41	4299	First Draw	Tap	Room 301	2	5/23/2018	
Sample 42	4300	First Draw	Bubbler	Room 301	3	5/23/2018	
Sample 43	4301	First Draw	Tap	Room 302	2	5/23/2018	
Sample 44	4302	First Draw	Bubbler	Room 304	1	5/23/2018	
Sample 45	4303	First Draw	Tap	Room 304	1	5/23/2018	
Sample 46	4304	First Draw	Bubbler	Room 305	2	5/23/2018	
Sample 47	4305	First Draw	Tap	Room 305	1	5/23/2018	
Sample 48	4306	First Draw	Bubbler	Room 306	3	5/23/2018	
Sample 49	4307	First Draw	Tap	Room 306	1	5/23/2018	
Sample 50	4308	First Draw	Bubbler	Room 307	<1	5/23/2018	
Sample 51	4309	First Draw	Tap	Room 307	<1	5/23/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 52	4310	First Draw	Tap	Room 308	2	8/20/2018	
Sample 53	4311	First Draw	Bubbler	Room 308	<1	8/20/2018	
Sample 54	4312	First Draw	Tap	Room 309	<1	5/23/2018	
Sample 55	4313	First Draw	Bubbler	Room 309	<1	5/23/2018	
Sample 56	4314	First Draw	Tap	Room 310	1	5/23/2018	
Sample 57	4315	First Draw	Bubbler	Room 310	<1	5/23/2018	
Sample 58	4316	First Draw	Tap	Room 311	2	8/20/2018	
Sample 59	4317	First Draw	Bubbler	Room 311	<1	8/20/2018	
Sample 60	4318	First Draw	Tap	Room 312	3	8/20/2018	
Sample 61	4319	First Draw	Bubbler	Room 312	<1	8/20/2018	
Sample 62	4320	First Draw	Tap	Room 313	<1	5/23/2018	
Sample 63	4321	First Draw	Bubbler	Room 313	<1	5/23/2018	
Sample 64	4322	First Draw	Bubbler	Near Room 418	<1	5/23/2018	Left Bubbler

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 65	4323	First Draw	Bubbler	Near Room 418	1	5/23/2018	Right Bubbler
Sample 66	4324	First Draw	Tap	Room 404	1	5/23/2018	
Sample 67	4325	First Draw	Bubbler	Room 404	<1	5/23/2018	
Sample 68	4326	First Draw	Tap	Room 405	<1	5/23/2018	
Sample 69	4327	First Draw	Bubbler	Room 405	1	5/23/2018	
Sample 70	4328	First Draw	Tap	Room 406	<1	5/23/2018	
Sample 71	4329	First Draw	Bubbler	Room 406	1	5/23/2018	
Sample 72	4330	First Draw	Tap	Room 407	1	5/23/2018	
Sample 73	4331	First Draw	Bubbler	Room 407	<1	5/23/2018	