



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Vancouver School District

School Name: Lieser Campus

School Code: N/A

Address: 301 S Lieser Rd Vancouver WA 98664

Number of Samples Collected: 47

Date Collected: 3/30/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	5657	First Draw	Blank	Blank	<1	5/18/2018	blank
Sample 2	5658	First Draw	Tap	Kitchen	<1	5/18/2018	left-hand tap, prep sink
Sample 3	5659	First Draw	Tap	Kitchen	TB		right-hand tap, prep sink
Sample 4	5660	First Draw	Bubbler	Early Childhood	<1	5/18/2018	left Upper
Sample 5	5661	First Draw	Bubbler	Early Childhood	<1	5/18/2018	right Lower
Sample 6	5662	First Draw	Bubbler	Rm. 19	44	5/18/2018	
Sample 7	5663	First Draw	Tap	Rm. 19	26	5/18/2018	
Sample 8	5664	First Draw	Water Cooler	Rm. 19	<1	5/18/2018	
Sample 9	5665	First Draw	Bubbler	Rm. 20	15	5/18/2018	
Sample 10	5666	First Draw	Tap	Rm. 20	15	5/18/2018	
Sample 11	5667	First Draw	Bubbler	Rm. 18	1	5/18/2018	
Sample 12	5668	First Draw	Tap	Rm. 18	7	5/18/2018	
Sample 13	5669	First Draw	Bubbler	Rm. 17	TB		
Sample 14	5670	First Draw	Tap	Rm. 17	34	5/18/2018	
Sample 15	5671	First Draw	Bubbler	South Hall/ Near Rm. 18	TB		left-hand bubbler, very closely joined piping
Sample 16	5672	First Draw	Bubbler	south Hall/ Near Rm. 18	<1	5/18/2018	right-hand bubbler, Low function, very closely joined piping
Sample 17	5673	First Draw	Tap	Rm. 16A	TB		possible Irregular use
Sample 18	5674	First Draw	Tap	Rm. 15	17	5/18/2018	bubbler no function

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 19	5675	First Draw	Bubbler	Rm. 14	1	5/18/2018	
Sample 20	5676	First Draw	Tap	Rm. 14	10	5/18/2018	
Sample 21	5677	First Draw	Bubbler	Rm. 13	1	5/18/2018	
Sample 22	5678	First Draw	Tap	Rm. 13	5	5/18/2018	
Sample 23	5679	First Draw	Bubbler	Rm. 12	3	5/18/2018	
Sample 24	5680	First Draw	Tap	Rm. 12	20	5/18/2018	
Sample 25	5681	First Draw	Bubbler	Rm. 11	12	5/18/2018	
Sample 26	5682	First Draw	Tap	Rm. 11	15	5/18/2018	
Sample 27	5683	First Draw	Bubbler	Middle Hall/ Across from Rm. 11	5	5/18/2018	left
Sample 28	5684	First Draw	Bubbler	Middle Hall/ Across from Rm. 12	1	5/18/2018	middle
Sample 29	5685	First Draw	Bubbler	Middle Hall/ Across from Rm. 13	TB		right
Sample 30	5686	First Draw	Bubbler	Rm .10	3	5/18/2018	
Sample 31	5687	First Draw	Tap	Rm. 10	12	5/18/2018	
Sample 32	5688	First Draw	Bubbler	Next to Business Office	<1	5/18/2018	left
Sample 33	5689	First Draw	Bubbler	Next to Business Office	<1	5/18/2018	right

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 34	5690	First Draw	Tap	Business office	<1	5/18/2018	only water in room
Sample 35	5691	First Draw	Bubbler	Rm. 7	2	5/18/2018	
Sample 36	5692	First Draw	Tap	Rm. 7	3	5/18/2018	
Sample 37	5693	First Draw	Bubbler	Rm. 6	3	5/18/2018	
Sample 38	5694	First Draw	Tap	Rm. 6	9	5/18/2018	
Sample 39	5695	First Draw	Bubbler	Rm. 5	3	5/18/2018	low function
Sample 40	5696	First Draw	Tap	Rm. 5	7	5/18/2018	
Sample 41	5697	First Draw	Tap	Rm. 4	28	5/18/2018	bubbler no function
Sample 42	5698	First Draw	Bubbler	North Hall/ Next to Rm. 4	<1	5/18/2018	left
Sample 43	5699	First Draw	Bubbler	North Hall/ Next to Rm. 4	1	5/18/2018	right
Sample 44	5700	First Draw	Tap	Rm. 3	16	5/18/2018	
Sample 45	5701	First Draw	Tap	Rm. 2	1	5/18/2018	bubbler turned off
Sample 46	5702	First Draw	Tap	Rm. 1	3	5/18/2018	left
Sample 47	5703	First Draw	Tap	Rm. 1	3	5/18/2018	right
Sample 48	5704	First Draw	Tap	Rm. 1	<1	5/18/2018	back room

TB= Turbidity, further analysis required.