



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School Name: Naches Trail Elementary

School Code:

School District Name: Bethel

Address: 15305 Waller Road E, Tacoma WA 98446

County: Pierce

Number of Samples Collected: 20

Date Collected: 08/27/2018

| Sample number | Sample ID | Sample Type | Fixture Description | Fixture Location | Lead Content (ppb) | Date of Analysis | Notes/Comments |
|---------------|-----------|-------------|---------------------|--------------------------|--------------------|------------------|---|
| 1. | 11823 | First Draw | Tap | Nurses Station | 9 | 08/30/2018 | 7:15 AM, all samples fixture replacements |
| 2. | 11824 | First Draw | Bubbler | Room 1 | 8509 | 08/30/2018 | |
| 3. | 11825 | First Draw | Tap | Room 2 | 14 | 08/30/2018 | |
| 4. | 11826 | First Draw | Tap | Room 3 | 12 | 08/30/2018 | |
| 5. | 11827 | First Draw | Bubbler | Room 4 | 33 | 08/30/2018 | |
| 6. | 11828 | First Draw | Bubbler | Computer Lab near Room 2 | 1012 | 08/30/2018 | |
| 7. | 11829 | First Draw | Tap | Computer Lab near Room 2 | 43 | 08/30/2018 | |
| 8. | 11830 | First Draw | Bubbler | Room 10 | 13 | 08/30/2018 | |
| 9. | 11831 | First Draw | Tap | Room 11 | TB | | |
| 10. | 11832 | First Draw | Bubbler | Room 12 | 6 | 08/30/2018 | |
| 11. | 11834 | First Draw | Bubbler | Room 13 | 4 | 08/30/2018 | |
| 12. | 11835 | First Draw | Tap | Room 14 | 4 | 08/30/2018 | |
| 13. | 11836 | First Draw | Tap | Room 15 | 6 | 08/30/2018 | |
| 14. | 11837 | First Draw | Bottle Filler | Room 16 | 5 | 08/30/2018 | |
| 15. | 11838 | First Draw | Tap | Room 17 | 9 | 08/30/2018 | |
| 16. | 11839 | First Draw | Tap | Room 19 | TB | | |
| 17. | 11840 | First Draw | Tap | Room 20 | 8 | 08/31/2018 | |
| 18. | 11841 | First Draw | Tap | Room 21 | 7 | 08/30/2018 | |

| Sample number | Sample ID | Sample Type | Fixture Description | Fixture Location | Lead Content (ppb) | Date of Analysis | Notes/Comments |
|---------------|-----------|-------------|---------------------|------------------|--------------------|------------------|--------------------|
| 19. | 11842 | First Draw | Tap | Computer Lab | 23 | 08/30/2018 | Across from Room 7 |
| 20. | 11843 | | | Computer Lab | <1 | 08/30/2018 | 03339 |

TB= Turbidity, further analysis required.