



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Federal Way School

School Name: Nautilus Elementary

School Code: 3625

Address: 1000 S 289th St Federal Way 98003

County: King

Number of Samples Collected: 52

Date Collected: 5/17/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	902	First Draw	Bubbler	Health Room	3	06/06/2018	
Sample 2	924	First Draw	Tap	Health Room	5	06/06/2018	
Sample 3	1048	First Draw	Bubbler	Room 1	4	06/06/2018	
Sample 4	1057	First Draw	Tap	Room 1	19	06/06/2018	
Sample 5	1062	First Draw	Bubbler	Room 2	7	8/29/2018	Discolored water
Sample 6	1063	First Draw	Tap	Room 2	5	06/06/2018	
Sample 7	1064	First Draw	Bubbler	Room 3	8	06/06/2018	
Sample 8	5257	First Draw	Tap	Room 3	11	8/29/2018	
Sample 9	8854	First Draw	Bubbler	Room 4	8	8/29/2018	
Sample 10	8855	First Draw	Tap	Room 4	2	06/06/2018	
Sample 11	8856	First Draw	Bubbler	Room 5	10	06/06/2018	
Sample 12	8857	First Draw	Tap	Room 5	5	8/29/2018	
Sample 13	8858	First Draw	Bubbler	Room 6	4	8/29/2018	
Sample 14	8859	First Draw	Tap	Room 6	3	8/29/2018	
Sample 15	8860	First Draw	Drinking Fountain	Gym, near restrooms	2	06/06/2018	
Sample 16	8861	First Draw	Bubbler	Room 7	5	06/06/2018	
Sample 17	8862	First Draw	Tap	Room 7	5	8/29/2018	
Sample 18	8863	First Draw	Bubbler	Room 8	3	8/29/2018	
Sample 19	8864	First Draw	Tap	Room 8	3	06/06/2018	
Sample 20	8865	First Draw	Bubbler	Room 9	3	06/06/2018	
Sample 21	8866	First Draw	Tap	Room 9	2	06/06/2018	
Sample 22	8867	First Draw	Bubbler	Room 10	4	06/06/2018	
Sample 23	8868	First Draw	Tap	Room 10	5	06/06/2018	
Sample 24	8869	First Draw	Bubbler	Room 11	2	06/06/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 25	8870	First Draw	Tap	Room 11	4	06/06/2018	
Sample 26	8871	First Draw	Bubbler	Room 12	2	8/29/2018	
Sample 27	8872	First Draw	Tap	Room 12	1	06/06/2018	
Sample 28	8873	First Draw	Bubbler	Room 13	2	06/06/2018	
Sample 29	8874	First Draw	Tap	Room 13	7	06/06/2018	
Sample 30	8875	First Draw	Bubbler	Room 14	<1	8/29/2018	
Sample 31	8876	First Draw	Tap	Room 14	<1	8/29/2018	
Sample 32	8877	First Draw	Bubbler	Room 15	3	06/06/2018	
Sample 33	8878	First Draw	Tap	Room 15	5	06/06/2018	
Sample 34	8879	First Draw	Bubbler	Room 16	3	06/06/2018	
Sample 35	8880	First Draw	Tap	Room 16	2	8/29/2018	tap used
Sample 36	8881	First Draw	Bubbler	Room 17	5	06/06/2018	
Sample 37	8882	First Draw	Tap	Room 17	5	8/29/2018	
Sample 38	8883	First Draw	Bubbler	Room 20	7	06/06/2018	
Sample 39	8884	First Draw	Tap	Room 20	8	06/06/2018	
Sample 40	8885	First Draw	Bubbler	Room 18	5	06/06/2018	
Sample 41	8886	First Draw	Tap	Room 18	8	06/06/2018	
Sample 42	8887	First Draw	Bubbler	Room 19	9	06/06/2018	
Sample 43	8888	First Draw	Tap	Room 19	9	06/06/2018	
Sample 44	8889	First Draw	Tap	Room 21	2	06/06/2018	
Sample 45	8890	First Draw	Bubbler	Room 23	6	06/06/2018	
Sample 46	8891	First Draw	Tap	Room 23	20	8/29/2018	No aerator

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 47	8892	First Draw	Bubbler	Room 22	86	8/29/2018	
Sample 48	8893	First Draw	Tap	Room 22	110	8/29/2018	
Sample 49	8894	First Draw	Bubbler	Room 25	4	06/06/2018	
Sample 50	8895	First Draw	Tap	Room 25	5	06/06/2018	
Sample 51	8896	First Draw	Bubbler	Room 24	25	8/29/2018	
Sample 52	8897	First Draw	Tap	Room 24	7	06/06/2018	very low flow
Sample 53	8898	First Draw	Blank	Staff Lounge	<1	06/06/2018	03424
	Notes:	Kitchen has no food prep sink or stove					