



**Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road SE, Tumwater WA 98501**

**Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**Please Note: The school is participating in follow up sampling and has followed recommendations to reduce children's exposure to lead in drinking water.**

**School Name:** Cascade Elementary School

**School Code:** 3659

**School District Name:** Eastmont

**Address:** 2330 N. Baker Ave East Wenatchee WA 98802

**County:** Douglas

**Number of Samples Collected:** 48

**Date Collected:** 10/25/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	13411	First Draw	Bubbler	Portable 702	<1	11/02/2018	
2.	13412	First Draw	Bubbler	Portable 703	<1	11/02/2018	
3.	13413	First Draw	Bubbler	Portable 703	<1	11/02/2018	
4.	13414	First Draw	Bubbler	Room A2	4	11/02/2018	
5.	13415	First Draw	Tap	Room A2	19	11/02/2018	
6.	13416	First Draw	Bubbler	Room A4	10	11/19/2018	
7.	13417	First Draw	Tap	Room A4	16	11/02/2018	
8.	13418	First Draw	Bubbler	Room a6	4	11/02/2018	
9.	13419	First Draw	Tap	Room A6	8	11/02/2018	
10.	13421	First Draw	Bubbler	Room A5	9	11/19/2018	
11.	13422	First Draw	Tap	Room a5	<1	11/02/2018	
12.	13423	First Draw	Bubbler	Room a1	8	11/02/2018	
13.	13424	First Draw	Tap	Room a1	5	11/02/2018	
14.	13425	First Draw	Tap	Room B1	7	11/02/2018	
15.	13426	First Draw	Bubbler	Room b1	3	11/02/2018	
16.	13427	First Draw	Tap	Room b2	7	11/02/2018	
17.	13428	First Draw	Bubbler	Room b2	5	11/02/2018	
18.	13429	First Draw	Tap	Room b3	5	11/02/2018	
19.	13430	First Draw	Bubbler	Room b3	1	11/02/2018	
20.	13431	First Draw	Tap	Room b4	44	11/19/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
21.	13432	First Draw	Bubbler	Room b4	5	11/02/2018	
22.	13433	First Draw	Tap	Room b5	11	11/02/2018	
23.	13434	First Draw	Bubbler	Room b5	9	11/02/2018	
24.	13435	First Draw	Tap	Room b6	10	11/19/2018	
25.	13436	First Draw	Bubbler	Room b6	11	11/19/2018	
26.	13437	First Draw	Bubbler	Portable 706-2	1	11/02/2018	
27.	13438	First Draw	Bubbler	Portable 706-1	6	11/02/2018	
28.	13439	First Draw	Tap	Room e1	<1	11/02/2018	
29.	13440	First Draw	Bubbler	Room e1	<1	11/02/2018	
30.	13441	First Draw	Tap	Room e2	1	11/02/2018	
31.	13442	First Draw	Bubbler	Room e2	6	11/02/2018	
32.	13443	First Draw	Tap	Room e3	<1	11/02/2018	
33.	13444	First Draw	Bubbler	Room e3	3	11/02/2018	
34.	13445	First Draw	Tap	Room e4	9	11/02/2018	
35.	13446	First Draw	Bubbler	Room e4	<1	11/02/2018	
36.	13447	First Draw	Tap	Room e5	<1	11/02/2018	
37.	13448	First Draw	Bubbler	Room e5	1	11/02/2018	
38.	13449	First Draw	Tap	Room e6	11	11/02/2018	
39.	13450	First Draw	Bubbler	Room e6	1	11/02/2018	
40.	13451	First Draw	Bubbler	Outside gym	<1	11/03/2018	Left

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
41.	13452	First Draw	Bubbler	Outside gym	<1	11/03/2018	Right
42.	13453	First Draw	Bubbler	Gym	3	11/03/2018	
43.	13454	First Draw	Bubbler	Multi purpose room	<1	11/03/2018	
44.	13455	First Draw	Tap	Multi purpose room	2	11/03/2018	
45.	13457	First Draw	Bubbler	Room c5	<1	11/03/2018	
46.	13458	First Draw	Tap	Room c5	<1	11/03/2018	
47.	13459	First Draw	Tap	Room c4	4	11/03/2018	
48.	13456	First Draw	Blank	Blank	<1	11/03/2018	