



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please note:

Once the school received the lead test results, the fixtures with elevated lead levels were removed and replaced with lead free fixtures. The school will conduct follow up lead testing to ensure that the replaced fixtures are safe to drink from before returning them to use.

School District Name: Asotin-Anatone School District

School Name: Asotin Elementary School

School Code: 2507

Address: 314 1st St. Asotin WA 99402

County: Asotin

Number of Samples Collected: 50

Date Collected: 5/15/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	8002	First Draw	BLANK	BLANK	<1	09/07/2018	
Sample 2	8003	First Draw	Bubbler	Near Room 111	<1	09/07/2018	
Sample 3	8004	First Draw	Bottle Filler	Near Room 111	<1	09/07/2018	
Sample 4	8005	First Draw	Tap	Room 111	5	09/07/2018	
Sample 5	8006	First Draw	Bubbler	Room 111	1	09/07/2018	
Sample 6	8007	First Draw	Tap	Room 110	<1	09/07/2018	
Sample 7	8008	First Draw	Bubbler	Room 110	<1	09/07/2018	
Sample 8	8009	First Draw	Tap	Room 109	1	09/07/2018	
Sample 9	8010	First Draw	Bubbler	Room 109	<1	09/07/2018	
Sample 10	8011	First Draw	Tap	Room 108	109	09/07/2018	
Sample 11	8012	First Draw	Bubbler	Room 108	<1	09/07/2018	
Sample 12	8013	First Draw	Tap	Room 107	<1	09/07/2018	
Sample 13	8014	First Draw	Bubbler	Room 107	1	09/07/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 14	8015	First Draw	Tap	Room 106	<1	09/07/2018	
Sample 15	8016	First Draw	Bubbler	Room 106	<1	09/07/2018	
Sample 16	8017	First Draw	Tap	Room 105	<1	09/07/2018	
Sample 17	8018	First Draw	Bubbler	Room 105	<1	09/07/2018	
Sample 18	8019	First Draw	Tap	Room 103	<1	09/07/2018	
Sample 19	8020	First Draw	Bubbler	Room 104	<1	09/07/2018	
Sample 20	8021	First Draw	Tap	Room 104	2	09/07/2018	
Sample 21	8022	First Draw	Tap	Room 102	<1	09/07/2018	
Sample 22	8023	First Draw	Tap	Main Office	<1	09/07/2018	
Sample 23	8024	First Draw	Bubbler	Main Office	<1	09/07/2018	
Sample 24	8025	First Draw	Bottle Filler	Near Room 120	<1	09/07/2018	
Sample 25	8026	First Draw	Bubbler	Near Room 120	<1	09/07/2018	
Sample 26	8027	First Draw	Tap	Room 120	1	09/07/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 27	8028	First Draw	Bubbler	Room 120	<1	09/07/2018	
Sample 28	8029	First Draw	Tap	Room 121	1	09/07/2018	
Sample 29	8030	First Draw	Bubbler	Room 121	<1	09/07/2018	
Sample 30	8031	First Draw	Tap	Kitchen	<1	09/07/2018	Personal Handwashing Sink by the Bathroom
Sample 31	8032	First Draw	Bubbler	Kitchen	1	09/07/2018	Used. Left Tap
Sample 32	8033	First Draw	Tap	Kitchen	<1	09/07/2018	Used. Right Tap
Sample 33	8034	First Draw	Tap	Room 119	<1	09/07/2018	
Sample 34	8035	First Draw	Bubbler	Room 119	<1	09/07/2018	
Sample 35	8036	First Draw	Tap	Room 117	8	8/20/2018	
Sample 36	8037	First Draw	Bubbler	Room 117	3	8/20/2018	
Sample 37	8038	First Draw	Bottle Filler	Near Room 117	<1	09/07/2018	
Sample 38	8039	First Draw	Bubbler	Near Room 117	<1	09/07/2018	
Sample 39	8040	First Draw	Tap	Room 118	7	8/20/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 40	8041	First Draw	Bubbler	Room 118	1	09/07/2018	
Sample 41	8042	First Draw	Tap	Room 116	<1	09/07/2018	
Sample 42	8043	First Draw	Bubbler	Room 116	<1	09/07/2018	
Sample 43	8044	First Draw	Tap	Room 114	<1	09/07/2018	
Sample 44	8045	First Draw	Bubbler	Room 114	<1	09/07/2018	
Sample 45	8046	First Draw	Tap	Room 115	<1	09/07/2018	
Sample 46	8047	First Draw	Bubbler	Room 115	<1	09/07/2018	
Sample 47	8048	First Draw	Tap	Room 112	<1	09/07/2018	
Sample 48	8049	First Draw	Bubbler	Room 112	<1	9/7/2018	
Sample 49	8050	First Draw	Tap	Room 113	<1	9/7/2018	
Sample 50	8051	First Draw	Bubbler	Room 113	<1	9/7/2018	