



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please note: The school district is participating in follow up testing to and is following all recommendations to reduce children's overall exposure to lead.

School District: Kent

School Name: George T. Daniel Elementary

School Code: 4413

School Address: 11310 Southeast 248th St, Kent Washington 98030

Number of Samples Collected: 66

Date Collected: 03/06/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
20435	other	other		<1	03/15/2019	06283, 6:46 AM
20533	FirstDraw	Tap	Main Office	3	03/15/2019	
20534	FirstDraw	Tap	Health Room	3	03/15/2019	
20535	FirstDraw	Bubbler	Cafeteria	<1	03/15/2019	
20536	FirstDraw	Bubbler	West Hallway 1st floor	<1	03/15/2019	Near A Rooms
20537	FirstDraw	Bubbler	East Hallway 1st Floor	<1	03/15/2019	
20538	FirstDraw	Bubbler	Gym	<1	03/15/2019	West Side of gym
20539	FirstDraw	Bubbler	Gym	<1	03/15/2019	East Side of Gym
20540	FirstDraw	Tap	Room D-8	1	03/15/2019	Left Tap
20541	FirstDraw	Tap	Room D-8	<1	03/15/2019	Right Tap
20542	FirstDraw	Tap	Room D-7	1	03/15/2019	Left Tap
20543	FirstDraw	Tap	Room D-7	<1	03/15/2019	Right Tap
20544	FirstDraw	Bubbler	Room D-6	5	03/15/2019	
20545	FirstDraw	Tap	Room D-6	2	03/15/2019	
20546	FirstDraw	Tap	Room D-6 Near Bathrooms	1	03/15/2019	Left Tap
20547	FirstDraw	Tap	Room D-6 near Bathrooms	1	03/15/2019	Right Tap
20548	FirstDraw	Bubbler	Room D-5	16	03/15/2019	
20549	FirstDraw	Tap	Room D-5	3	03/15/2019	Dripping, not turned off all the way
20550	FirstDraw	Bubbler	Room D-6	<1	03/15/2019	Near Back of Room
20551	FirstDraw	Bubbler	Room D-5	1	03/15/2019	Near Back of Room
20552	FirstDraw	Bubbler	Room D-4	2	03/15/2019	
20553	FirstDraw	Tap	Room D-4	2	03/15/2019	
20554	FirstDraw	Tap	Room D-3	1	03/15/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
20556	FirstDraw	Tap	Staff Lounge	1	03/15/2019	Water Feels Warm, Hot Tap Used Previously
20557	FirstDraw	Tap	Library	<1	03/15/2019	
20558	FirstDraw	Bubbler	Room G-1	1	03/15/2019	
20559	FirstDraw	Tap	Room G-1	3	03/15/2019	
20560	FirstDraw	Bubbler	Room G-2	2	03/15/2019	
20561	FirstDraw	Tap	Room G-2	3	03/15/2019	Tap Dripping
20562	FirstDraw	Bubbler	Room A-1	2	03/15/2019	
20563	FirstDraw	Tap	Room A-1	3	03/15/2019	
20564	FirstDraw	Bubbler	Room A-2	<1	03/15/2019	
20565	FirstDraw	Tap	Room A-2	5	03/15/2019	
20566	FirstDraw	Bubbler	Room A-3	2	03/15/2019	
20567	FirstDraw	Tap	Room A-3	3	03/15/2019	No Aerator, Some buildup on tap, water drip
20568	FirstDraw	Bubbler	Room A-4	1	03/15/2019	
20569	FirstDraw	Tap	Room A-4	1	03/15/2019	No Aerator Some Buildup on Tap
20570	FirstDraw	Bubbler	Room A-5	1	03/15/2019	
20571	FirstDraw	Tap	Room A-5	3	03/15/2019	
20572	FirstDraw	Bubbler	Room A-6	<1	03/15/2019	
20573	FirstDraw	Tap	Room A-6	2	03/15/2019	
20574	FirstDraw	Bubbler	Outside Room E-9	<1	03/15/2019	
20575	FirstDraw	Bubbler	Room E-6	<1	03/15/2019	
20576	FirstDraw	Tap	Room E-6	6	03/15/2019	
20577	FirstDraw	Bubbler	Room E-5	1	03/15/2019	
20578	FirstDraw	Tap	Room E-5	4	03/15/2019	
20579	FirstDraw	Bubbler	Room E-4	<1	03/15/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
20580	FirstDraw	Tap	Room E-4	3	03/15/2019	
20581	FirstDraw	Bubbler	Room E-3	1	03/15/2019	
20582	FirstDraw	Tap	Room E-3	3	03/15/2019	
20583	FirstDraw	Bubbler	Room E-2	1	03/15/2019	
20584	FirstDraw	Tap	Room E-2	3	03/15/2019	
20585	FirstDraw	Bubbler	Room E-1	<1	03/15/2019	
20586	FirstDraw	Tap	Room E-1	4	03/15/2019	
20587	FirstDraw	Bubbler	Room F-1	1	03/15/2019	
20588	FirstDraw	Tap	Room F-1	6	03/15/2019	No Aerator
20589	FirstDraw	Bubbler	Room F-2	<1	03/15/2019	Usend this morning
20590	FirstDraw	Tap	Room F-2	3	03/15/2019	Used this morning
20591	FirstDraw	Bubbler	Room F-3	1	03/15/2019	Used this morning
20592	FirstDraw	Tap	Room F-3	2	03/16/2019	Hot Tap used this morning
20593	FirstDraw	Bubbler	Room F-4	<1	03/16/2019	Used this morning
20594	FirstDraw	Tap	Room F-4	2	03/16/2019	Used this morning
20595	FirstDraw	Bubbler	Room F-5	1	03/16/2019	
20596	FirstDraw	Tap	Room F-5	3	03/16/2019	
20597	FirstDraw	Bubbler	Room F-6	<1	03/16/2019	
20598	FirstDraw	Tap	Room F-6	2	03/16/2019	