



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Per the district, all fixtures above 19 ppb were replaced with lead free fixtures and some fixtures were permanently removed. For all fixtures between 2 and 19 ppb the district has implemented a flushing plan.

School Name: Clallam Bay Elementary

School Code: 3422

School District Name: Cape Flattery

Address: 16-933 Hwy 112, Clallam Bay WA 98326

County: Clallam

Number of Samples Collected: 16

Date Collected: 11/15/2018:

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	17813	First Draw	Tap	Faculty Hall sink	22	12/19/2018	
2.	17814	First Draw	Tap	Faculty back sink	16	11/29/2018	
3.	17815	First Draw	Bubbler	3rd Grade	1	11/29/2018	
4.	17816	First Draw	Tap	3rd Grade	2	11/29/2018	
5.	17817	First Draw	Bubbler	Kindergarten	1	11/29/2018	
6.	17818	First Draw	Tap	Kindergarten	1	11/29/2018	
7.	17819	First Draw	Bubbler	2nd Grade/1st Grade	1	11/29/2018	
8.	17820	First Draw	Tap	2nd Grade/1st Grade	3	11/29/2018	
9.	17821	First Draw	Bubbler	LAP Room	5	11/29/2018	
10.	17822	First Draw	Tap	LAP Room	5	11/29/2018	
11.	17823	First Draw	Bubbler	4th Grade	1	11/29/2018	
12.	17824	First Draw	Tap	4th Grade	2	12/19/2018	
13.	17825	First Draw	Bubbler	Gym	1	11/29/2018	Left
14.	17826	First Draw	Bubbler	Gym	5	11/29/2018	Right
15.	17827	First Draw	Tap	Gym Concessions	7	11/29/2018	Possibly irregular use
16.	17828				1	11/29/2018	